



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 06, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20221793

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construction of a swim school including the pool in the former Sears  
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1. hot water lines insulation approved  
2. complete items from previous list

**Corrections:**

- 1 1.framing of walls at demising wall south approved can cover one side
- 2.provide insulation on hot water lines
3. provide fire protection at electrical boxes in rated walls
4. no ceilings approved for cover
5. did not look at any mechanical

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590