



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 12, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20230098

Property Address: 1015 39TH AVE SE, PUYALLUP, WA 98374;

Contractor: JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 702-8193

To construct: Tenant improvement and finish out of the North side of level 1. Improvements include offices, meeting rooms, cardio area, and break rooms. The interior alterations do not increase the building's area, nor do they alter the building egress and/or circulation outside the renovated space. REVISION (1) - 03/17/2023 - OPEN CEILING IN SOME AREAS, CEILING DETAILS, DOOR & WINDOW SCHEDULE UPDATES

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; drywall nailing complete at 2nd floor patch of shaft at 2nd floor.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org