



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 13, 2023

**Inspection Result:** NOT READY

**Permit Number:** PRCTI20230098

**Property Address:** 1015 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** JTM CONSTRUCTION 5900 AIRPORT WAY SOUTH, #110 SEATTLE, WA 98108 (206) 702-8193

**To construct:** Tenant improvement and finish out of the North side of level 1. Improvements include offices, meeting rooms, cardio area, and break rooms. The interior alterations do not increase the building's area, nor do they alter the building egress and/or circulation outside the renovated space. REVISION (1) - 03/17/2023 - OPEN CEILING IN SOME AREAS, CEILING DETAILS, DOOR & WINDOW SCHEDULE UPDATES

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1 ; complete perimeter tie wires as discussed with ceiling contractor.
- 2 ; provide min 3 complete turns at all tie wires of lights.
- 3 ; complete positive attachment of diffusers to main and cross-tee of ceiling grid.
- 4 ; complete wall angles at smoke/fire dampers. ( complete fire damper labels as discussed with contractor prior to ceiling cover inspection approval.)
- 6 ; complete marking of firewalls as discussed with contractor.
- 7 ; inspection at north side of building only.
- 2 1.complete items from previous list

Sincerely,



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Kevin Spruell

Building Inspector I

[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)

(253) 841-5590