



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 16, 2023

Inspection Result: PARTIAL PASS

Permit Number: E-21-0444

Property Address: 431 39TH AVE SW, PUYALLUP, WA 98373;

Contractor: CENTURY LINK 23315 66TH AVE S KENT, WA 98032

To construct: JOB # N.764248 REVISION TO PERMIT E-20-0408 EXTENSION PROVIDED
TO 9/7/22 FOR RESTORATION CT

On this day we have inspected your construction for **Comment Engineering Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Per my meeting with Dan Daffern from Rainier Asphalt, it was determined that although the overlay in both eastbound lanes at the trench patch is not smooth, the paving has experienced settlement or compacted to an extent that it was marginally acceptable and will not require a re-do. The transition at the manhole in the intersection of 39th and 5th is quite bumpy and it appears that a portion of the lid may be below grade. An email request will be sent to Lumen to explore and rectify this issue.

Corrections:

Sincerely,

Cheryl Trimble

Engineer Tech II

CTrimble@PuyallupWA.gov

(253) 841-5464



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org