



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 21, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20221793

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construction of a swim school including the pool in the former Sears  
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Plumbing Below Slab Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1; approved below slab plumbing test only of plumbing as per Health Department report of pool.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684