



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 21, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: PRCTI20221793

Property Address: 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construction of a swim school including the pool in the former Sears
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Wallboard / Drywall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; approved drywall nailing of walls only in rooms - (101,115)

Corrections:

- 1 1 ; inspection of drywall nailing complete at grid line- (H-J,9-13) except rooms 102,109,115 (not ready at time of inspection)
- 3 ;provide min. 1" gap at drywall to pan deck as required at deflection track as noted on City approved plans.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org