



City of Puyallup

**Fire Prevention**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jun 26, 2023

**Inspection Result:** PASSED

**Permit Number:** PRFA20220979

**Property Address:** 300 RIVER RD, PUYALLUP, WA 98371;

**Contractor:** E-SQUARED SYSTEMS LLC PO BOX 731227 PUYALLUP, WA 98373

**To construct:** Install new potter afc-1000 addressable fire alarm panel in group b occupancy in remodeled building and in existing maintenance bay building. Install initiation and notification to Puyallup and state fire code requirements. Provide fire alarm visual and audible notification on exterior of building and throughout building space within scope. Provide smoke detection and pull stations throughout. Building is sprinkled. Provide fire alarm central monitoring via Telco Lines.

On this day we have inspected your construction for **Fire Alarm Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

Sincerely,

David Drake  
Building Inspector II  
DDrake@PuyallupWA.gov  
(253) 864-4171



City of Puyallup

---

**Fire Prevention**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)