



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 21, 2023

Inspection Result: **FAILED**

Permit Number: PRFA20220979

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: E-SQUARED SYSTEMS LLC PO BOX 731227 PUYALLUP, WA 98373

To construct: Install new potter afc-1000 addressable fire alarm panel in group b occupancy in remodeled building and in existing maintenance bay building. Install initiation and notification to Puyallup and state fire code requirements. Provide fire alarm visual and audible notification on exterior of building and throughout building space within scope. Provide smoke detection and pull stations throughout. Building is sprinkled. Provide fire alarm central monitoring via Telco Lines.

On this day we have inspected your construction for **Fire Alarm Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1) Provide device graphic at annunciator.
2) Review code for separation from HVAC
3) As-built update for document box and email to City ddrake@puyallupwa.gov

Corrections:

Sincerely,

Ray Cockerham



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Code Official
RayC@PuyallupWA.gov
(253) 841-5585