



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jun 27, 2023

Inspection Result: **PASSED**

Permit Number: PRCCP20220092

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW
GIG HARBOR, WA 98332

To construct: Construct underground utilities, storm drainage, replacements of concrete curb, gutter, sidewalk, re-align driveway, replace driveways. Remove & replace asphalt paving.

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: street light final inspection passed. Condition number 6 states that if a possible strike hazard on the FDC, PIV, or existing hydrant exists that bollards will be installed. After review there is a chance of something backing into the existing hydrant on the north side. Bollards shall be installed on the north side. This item has been added to the punchlist in conjunction with raising the existing hydrant.

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424