



LIGHTING COMPLIANCE SUMMARY

2018 WSEC Compliance Forms for Commercial Buildings including Group R2, R3 & R4 over 3 stories and all R1

Administered by: ©2022 NEEA, All rights reserved

Project & Applicant Information	Project Title	Prologis- Puyallup 1- Suite 103 T.I. - 2018 WSEC		For Building Department Use:  	Date: Jun 23, 2022
	Project Address	1601 Industrial Park Way Suite 103 Puyallup, WA 98371			
	Applicant Name	Alex Wright			
	Applicant Phone	206-324-4800			
	Applicant Email	alex.wright@jacksonmain.com			
For questions about this report, contact WSEC Commercial Technical Support at 360-539-5300 or via email at com.techsupport@waenergycodes.com					

General Occupancy	All Commercial		General Building Use Type		Warehouse, General Storage	Building Cond. Floor Area	384,794
General Project Types	Alteration Change in Occupancy (Group F, S or U converted to another commercial occupancy)	New Building or Addition Lighting Scope		Alteration Lighting Scope	Interior Lighting	Project Cond. Floor Area	384,794
						Floors Above Grade	1
						Compliance Method	Compliance Method 1 - General
Lighting Project Description	Tenant Improvement to build a new office (B) within an existing warehouse (S-1). The area of work is 2,755 SF. There is no change to exiting.						

Lighting Compliance Scope and Method	Project Type	Interior / Exterior (Interior includes both interior & parking)	Luminaire Replacement Scope	Compliance Method	LPA Calculation Adjustment	Compliance Verification
	Alteration	Interior Lighting	50% or more replaced	Building area	No Calculation Adjustments allowed	COMPLIES
	Change in Occupancy	Interior Lighting		Building area	No Calculation Adjustments selected	COMPLIES
Additional Efficiency Options Included						

Project Title	Prologis- Puyallup 1- Suite 103 T.I. - 2018 WSEC				Date	Jun 23, 2022
Lighting Power Calculation	ALTERATION - INTERIOR LIGHTING (50% or more replaced)				Compliance Verification	COMPLIES
Compliance Method	Building area		LPA Calculation Adjustment			none

Interior Lighting Power Allowance - Building Area					
Building Areas	Gross Interior Area (SF)	LPA (Watts/SF)	Total Watts Allowed (SF x LPA x 1)	Total Proposed Watts By Building Area	Compliance Status by Building Area
Office	3,279	0.64	2,099	1,424	COMPLIES

Proposed Lighting Power Density								
Fixture Type/Application	Fixture ID	Building Area	New or Existing-to-Remain	Quantity of Fixtures, CLDs or Luminaires (#F)	Watts per Fixture, CLD or Luminaire (WpF)	Total Linear Feet (LF)	Watts per Linear Foot (WpLF)	Total Watts Proposed (#F x WpF) or (LF x WpLF)
Individual Fixtures								
Troffer	2'x4' LED Recessed Troffer Fixture	Office	New	26	36			936
Troffer	2'x4' LED Recessed Troffer Lighting Fixture with Integral Emergency Battery Backup	Office	New	5	36			180
Recessed downlight	6" Recessed Can Light	Office	New	14	22			308

Project Title	Prologis- Puyallup 1- Suite 103 T.I. - 2018 WSEC				Date	Jun 23, 2022
Proposed Fixtures Details	ALTERATION - INTERIOR LIGHTING (50% or more replaced)					

Fixture Type/Application	Fixture ID	Location in Documents	Lamp Type	Building Area	New or Existing-to-Remain
Individual Fixtures					
Troffer	2'x4' LED Recessed Troffer Fixture	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer Finish Standards	LED	Office	New
	Fixture Description: 2'x4' LED Recessed Troffer Lighting Fixture for the Office Space			Are these fixtures located within a daylight zone?: Yes, controls provided	
	Daylight zone location(s): Sidelit daylight zones (primary and/or secondary)			Dimming method: Continuous dimming	
	Do these fixtures require specific application lighting controls?: None required				
Troffer	2'x4' LED Recessed Troffer Lighting Fixture with Integral Emergency Battery Backup	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer Finish Standards	LED	Office	New
	Fixture Description: 2'x4' LED Recessed Troffer Lighting Fixture Integral Emergency Battery Backup for the Office Spaces			Are these fixtures located within a daylight zone?: Yes, controls provided	
	Daylight zone location(s): Sidelit daylight zones (primary and/or secondary)			Dimming method: Continuous dimming	
	Do these fixtures require specific application lighting controls?: Exit access & egress lighting per IBC Section 1006.1				
Recessed downlight	6" Recessed Can Light	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer Finish Standards	LED	Office	New
	Fixture Description: 6" Recessed Can Light for Office Restrooms			Are these fixtures located within a daylight zone?: No	
	Do these fixtures require specific application lighting controls?: None required				

Project Title	Prologis- Puyallup 1- Suite 103 T.I. - 2018 WSEC			Date	Jun 23, 2022
Lighting Power Calculation		CHANGE IN OCCUPANCY - INTERIOR LIGHTING		Compliance Verification	
Compliance Method		Building area	LPA Calculation Adjustment		none

Interior Lighting Power Allowance - Building Area					
Building Areas	Gross Interior Area (SF)	LPA (Watts/SF)	Total Watts Allowed (SF x LPA x 1)	Total Proposed Watts By Building Area	Compliance Status by Building Area
Office	3,279	0.64	2,099	1,424	COMPLIES

Proposed Lighting Power Density								
Fixture Type/Application	Fixture ID	Building Area	New or Existing-to-Remain	Quantity of Fixtures, CLDs or Luminaires (#F)	Watts per Fixture, CLD or Luminaire (WpF)	Total Linear Feet (LF)	Watts per Linear Foot (WpLF)	Total Watts Proposed (#F x WpF) or (LF x WpLF)
Individual Fixtures								
Troffer	2'x4' LED Recessed Troffer Lighting Fixture	Office	New	26	36			936
Troffer	2'x4' LED Recessed Troffer Lighting Fixture with Integral Emergency Battery Backup	Office	New	5	36			180
Recessed downlight	6" Recessed Can Light	Office	New	14	22			308

Project Title	Prologis- Puyallup 1- Suite 103 T.I. - 2018 WSEC			Date	Jun 23, 2022
Proposed Fixtures Details		CHANGE IN OCCUPANCY - INTERIOR LIGHTING			
Fixture Type/Application	Fixture ID	Location in Documents	Lamp Type	Building Area	New or Existing-to-Remain
Individual Fixtures					
Troffer	2'x4' LED Recessed Troffer Lighting Fixture	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer Finish Standards	LED	Office	New
	Fixture Description: 2'x4' LED Recessed Troffer Lighting Fixture for the Office Spaces			Are these fixtures located within a daylight zone?: Yes, controls provided	
	Daylight zone location(s): Sidelit daylight zones (primary and/or secondary)			Dimming method: Continuous dimming	
	Do these fixtures require specific application lighting controls?: None required				
Troffer	2'x4' LED Recessed Troffer Lighting Fixture with Integral Emergency	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer	LED	Office	New

PRCTI20221019

	Battery Backup	Finish Standards			
	Fixture Description: 2'x4' LED Recessed Troffer Lighting Fixture Integral Emergency Battery Backup for the Office Spaces			Are these fixtures located within a daylight zone?: Yes, controls provided	
	Daylight zone location(s): Sidelit daylight zones (primary and/or secondary)			Dimming method: Continuous dimming	
	Do these fixtures require specific application lighting controls?: Exit access & egress lighting per IBC Section 1006.1				
Recessed downlight	6" Recessed Can Light	A1.1 Office Ceiling and Lighting Plan, A4.1 Prologis Customer Finish Standards	LED	Office	New
	Fixture Description: 6" Recessed Can Light for the Office Restrooms			Are these fixtures located within a daylight zone?: No	
	Do these fixtures require specific application lighting controls?: None required				

THE APPROVED CONSTRUCTION PLANS, DOCUMENTS AND ALL ENGINEERING MUST BE POSTED ON THE JOB AT ALL INSPECTIONS IN A VISIBLE AND READILY ACCESSIBLE LOCATION.

FULL SIZED LEDGIBLE COLOR PLANS ARE REQUIRED TO BE PROVIDED BY THE PERMITEE ON SITE FOR INSPECTION