



8600 W Bryn Mawr Avenue  
Suite 800N  
Chicago, IL 60631  
847.788.9200  
www.greenbergfarrow.com  
Designing Solutions Together

## STRUCTURAL CALCULATIONS FOR

# RETAIL TENANT IMPROVEMENT


Bath & Body Works – SOUTH HILL MALL (Remote Storage)

Space No. 235

3500 S. Meridian Street

Puyallup, WA 98373

REV	Issue Date	Issue	Revised/Added Pages
	4/20/2023		Initial Calc Submittal



GF Project # 20221012.0

Building Code: 2018 International Building Code




**GENERAL STANDARD JOIST ANALYSIS**  
**For Steel Joists Considered as Simple-Span Beams**  
**Subjected to Non-Standard Loads**

Job Name:	BBW SOUTH HILL - REMOTE STORAGE	Subject:	AHU 1
Job Number:	20221012.0	Originator:	AD
		Checker:	MH

**Input Data:**

**Joist Data:**

Designation = **K-series**  
 Span, L = **50.0000** ft. TO BE V.I.F.  
 Modulus, E = **29000000** psi  
 Inertia, Ix = **731.45** in.<sup>4</sup>



**Original Design or Capacity Loads:**

**Full Uniform:**

W = **366** lbs./ft. 32LH07 @ 7'-6", TO BE V.I.F.

Distributed:	Start		End	
	b (ft.)	Wb (lbs./ft.)	e (ft.)	We (lbs/ft.)
#1:				
#2:				
#3:				
#4:				
#5:				
#6:				
#7:				
#8:				

Moments:	c (ft.)	M (ft-lbs)
#1:		
#2:		
#3:		
#4:		

**Nomenclature**

Point Loads:	a (ft.)	P (lbs.)
#1:		
#2:		
#3:		
#4:		
#5:		
#6:		
#7:		
#8:		
#9:		
#10:		
#11:		
#12:		
#13:		
#14:		
#15:		

**New Design Loads:**

**Full Uniform:**

w = **277.5** lbs./ft.

Distributed:	Start		End	
	b (ft.)	Wb (lbs./ft.)	e (ft.)	We (lbs/ft.)
#1:				
#2:				
#3:				
#4:				
#5:				
#6:				
#7:				
#8:				

Moments:	c (ft.)	M (ft-lbs)
#1:		
#2:		
#3:		
#4:		

Point Loads:	a (ft.)	P (lbs.)
#1:	10.00	41.75
#2:	11.60	41.75
#3:		
#4:		
#5:		
#6:		
#7:		
#8:		
#9:		
#10:		
#11:		
#12:		
#13:		
#14:		
#15:		

**Results of Joist Analysis:**

**Original Design or Capacity Loads:**

**End Reactions:**

RL =  lbs.

RR =  lbs.

**Minimum Design Web Member Shear:**

$V_w(\min) =$  lbs. (25% of maximum end reaction for K-series and LH-series joists per SJI Spec's.)

**Maximum Moments:**

+Mx(max) =  ft-lbs

@ X =  ft.

-Mx(max) =  ft-lbs

@ X =  ft.

**\*Maximum Deflections:**

- $\Delta(\max) =$  in.

@ X =  ft.

+ $\Delta(\max) =$  in.

@ X =  ft.

$\Delta(\text{ratio}) =$

*\*Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

**New Design Loads:**

**End Reactions:**

RL =  lbs.

RR =  lbs.

**Maximum Moments:**

+Mx(max) =  ft-lbs

@ X =  ft.

-Mx(max) =  ft-lbs

@ X =  ft.

**\*Maximum Deflections:**

- $\Delta(\max) =$  in.

@ X =  ft.

+ $\Delta(\max) =$  in.

@ X =  ft.

$\Delta(\text{ratio}) =$

*\*Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

**Maximum Stress Ratios:**


S.R. =  for Shear

@ X =  ft.

S.R. =  for Moment

@ X =  ft.

**Comments:**




**GENERAL STANDARD JOIST ANALYSIS**  
For Steel Joists Considered as Simple-Span Beams  
Subjected to Non-Standard Loads

Job Name:	BBW SOUTH HILL - REMOTE STORAGE	Subject:	CU 1
Job Number:	20221012.0	Originator:	AD
		Checker:	MH

**Input Data:**

**Joist Data:**

Designation = **K-series**  
 Span, L = **50.0000** ft. TO BE V.I.F.  
 Modulus, E = **29000000** psi  
 Inertia, Ix = **731.45** in.<sup>4</sup>



**Original Design or Capacity Loads:**

**Full Uniform:**

W = **366** lbs./ft. 32LH07 @ 7'-6", TO BE V.I.F.

Distributed:	Start		End	
	b (ft.)	Wb (lbs./ft.)	e (ft.)	We (lbs/ft.)
#1:				
#2:				
#3:				
#4:				
#5:				
#6:				
#7:				
#8:				

Moments:	c (ft.)	M (ft.-lbs)
#1:		
#2:		
#3:		
#4:		

**Nomenclature**

Point Loads:	a (ft.)	P (lbs.)
#1:		
#2:		
#3:		
#4:		
#5:		
#6:		
#7:		
#8:		
#9:		
#10:		
#11:		
#12:		
#13:		
#14:		
#15:		

**New Design Loads:**

**Full Uniform:**

w = **277.5** lbs./ft.

Distributed:	Start		End	
	b (ft.)	Wb (lbs./ft.)	e (ft.)	We (lbs/ft.)
#1:	4.9200	80.5	7.3300	80.5
#2:				
#3:				
#4:				
#5:				
#6:				
#7:				
#8:				

Moments:	c (ft.)	M (ft.-lbs)
#1:		
#2:		
#3:		
#4:		

Point Loads:	a (ft.)	P (lbs.)
#1:		
#2:		
#3:		
#4:		
#5:		
#6:		
#7:		
#8:		
#9:		
#10:		
#11:		
#12:		
#13:		
#14:		
#15:		

**Results of Joist Analysis:**

**Original Design or Capacity Loads:**

**End Reactions:**

RL =  lbs.      RR =  lbs.

**Minimum Design Web Member Shear:**

$V_w(\min) =$  lbs. (25% of maximum end reaction for K-series and LH-series joists per SJI Spec's.)

**Maximum Moments:**

+Mx(max) =  ft-lbs      @ X =  ft.  
-Mx(max) =  ft-lbs      @ X =  ft.

**\*Maximum Deflections:**

- $\Delta(\max) =$  in.      @ X =  ft.  
+ $\Delta(\max) =$  in.      @ X =  ft.  
 $\Delta(\text{ratio}) =$

*\*Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

**New Design Loads:**

**End Reactions:**

RL =  lbs.      RR =  lbs.

**Maximum Moments:**

+Mx(max) =  ft-lbs      @ X =  ft.  
-Mx(max) =  ft-lbs      @ X =  ft.

**\*Maximum Deflections:**


- $\Delta(\max) =$  in.      @ X =  ft.  
+ $\Delta(\max) =$  in.      @ X =  ft.  
 $\Delta(\text{ratio}) =$

*\*Note: deflections shown above include a 15% increase above the values calculated using traditional "simple-beam" flexure in order to more closely match actual test results obtained by SJI.*

**Maximum Stress Ratios:**

S.R. =  for Shear      @ X =  ft.  
S.R. =  for Moment      @ X =  ft.

**Comments:**






ASCE 7-16 WIND LOADING ON MECHANICAL EQUIPMENT

Wind Design Criteria

$F_v = q_h GC_r A_r$  (Eq. 29.4-3)

$q_h = 0.00256 K_h K_{zt} K_d K_e V^2$ (Equation 26.10-1)	
$z = 19.00$ ft	$K_d = 0.85$ (Table 26.6-1)
$K_h = 0.89$ (Table 26.10-1)	$K_e = 0.98$ (Table 26.9-1)
$K_{zt} = 1.00$ (Section 26.8.2)	$V = 97$ mph
$z_g = 433.00$ (ft)	
$q_z = 17.98$ psf	

<b>Uplift on Mechanical Unit</b>	
$F_v = q_h GC_r A_r$	
$GC_r = 1.5$	(Eq 29.4-3)
$W_r = 26.97$	x $A_r$



Uplift on Mechanical Units									
Unit(s)	Weight D (lbs)	Ar (ft <sup>2</sup> )	Ah (ft <sup>2</sup> )	X (ft)	Curb Length (ft)	Curb Width (ft)	Fv (lbs)	Net Uplift 0.6W-0.6D (lbs)	Curb Uplift (plf)
CU 1	161	6.88	6.65	2.38	2.75	2.50	185	15	1

$A_r$  = Width x Length

$A_h$  = Height x Length

x = Component center of gravity above point of attachment

- Uplift = Unit Weight > Uplift Load

**Connection Notes:**

Connect CU Curb to Framing w/ 1/8"x2"X10" Plate w/ (4) #12 screws ea. Curb

Tallow = 383 lbs (Wood Connection)

Tallow = 353.75 lbs (Cold-Formed Connection)

Tallow = 707.5 lbs per plate (Tension)

Straps have adequate capacity






**ASCE 7-16 WIND LOADING ON MECHANICAL EQUIPMENT**

**Wind Design Criteria**

$F_h = q_h GC_r Af$  (Eq. 29.4-2)

<b><math>q_h = 0.00256 K_h K_{zt} K_d K_e V^2</math> (Equation 26.10-1)</b>			
<b>z =</b> 19.00 ft	<b>K<sub>d</sub> =</b> 0.85 (Table 26.6-1)	<b>K<sub>e</sub> =</b> 0.98 (Table 26.9-1)	<b>V =</b> 97 mph
<b>K<sub>h</sub> =</b> 0.89 (Table 26.10-1)			
<b>K<sub>zt</sub> =</b> 1.00 (Section 26.8.2)			
<b>q<sub>z</sub> = 17.98 psf</b>			

<b>Lateral on Mechanical Unit</b>	
<b><math>F_h = q_h GC_r A_f</math></b>	
<b>GC<sub>r</sub> =</b> 1.9 (Eq 29.4-2)	
<b><math>F_h = 34.17 \times A_f</math></b>	



<b>Combined Lateral &amp; Uplift on Mechanical Units</b>											
Unit(s)	Weight D (lbs)	A <sub>h</sub> (ft <sup>2</sup> )	X (ft)	Curb Length (ft)	Curb Width (ft)	F <sub>v</sub> (lbs)	F <sub>h</sub> (lbs)	M <sub>OT</sub> (0.6W) (lb-ft)	M <sub>R</sub> (0.6D) (lb-ft)	Tension (0.6W-0.6D) (lbs)	T (plf)
CU 1	161	6.646	2.38	2.75	2.5	185	15	160	120.75	16	6

A<sub>h</sub> = Height x Length

x = Component center of gravity above point of attachment

- T = Resisting Moment > Overturning Moment, no tension loads

**Connection Notes:**

Connect CU Curb to Framing w/ 1/8"x2"X10" Plate w/ (4) #12 screws ea. Curb

Tallow = 383 lbs (Wood Connection)

Tallow = 353.75 lbs (Cold-Formed Connection)

Tallow = 707.5 lbs per plate (Tension)

Straps have adequate capacity



ASCE 7-16 SEISMIC LOADING ON NONSTRUCTURAL COMPONENTS

Seismic Design Criteria	
$S_{DS}$ =	1.011 ft
$h$ =	19.00 ft (Average Roof Height)

Component Input									
Component	Weight (lbs)	$a_p$	$R_p$	$z$ (ft)	$I_p$	$x$ (ft)	Length (ft)	Width (ft)	$z/h$
CU 1	161	2.50	6.00	19.00	1.00	2.38	2.75	2.50	1.00

$a_p$  &  $R_p$  = Per ASCE 7-16 Table 13.5-1 or 13.6-1  
 $z$  = Height in structure of point of attachment w/ respect to base  
 $x$  = Component center of gravity above point of attachment

Component Seismic Calculations										
Fp Limit (13.3-2)	Fp Limit (13.3-3)	Fp Calculated (Eq. 13.3-1)		Fp Design (lbs)		± Vert Force (lbs) (Section 13.3.1.2)	$M_{OT}$ (0.7 $E_n$ ) (ft-lbs)	$M_R$ (0.6D-0.7 $E_v$ )** (ft-lbs)	Tension (plf)	Tension (lbs)
		Component	Connection	Component	Connection					
260.4	48.8	81.4	81.4	81.4	81.4	32.6	135.3	92.3	6.3	17.2

\*\* $M_R$  assumes worst case direction  
 - Tension = Resisting Moment > Overturning Moment, no tension loads

**Connection Notes:**

Connect CU Curb to Framing w/ 1/8"x2"X10" Plate w/ (4) #12 screws ea. Curb  
 Tallow = 383 lbs (Wood Connection)  
 Tallow = 353.75 lbs (Cold-Formed Connection)  
 Tallow = 707.5 lbs per plate (Tension)  
 Straps have adequate capacity