

### City of Puyallup

#### **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

#### INSPECTION REPORT

**Date of Inspection:** Jun 30, 2023 **Inspection Result: NOT READY** 

Permit Number: PRCA20220091

**Property Address:** 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW

GIG HARBOR, WA 98332 WASHINGTON PATRIOT CONST LLC 10421

BURNHAM DR SUITE NW GIG HARBOR, WA 98332

**To construct:** Demolition of existing showroom module; Construction of a new 10,636

SF showroom module; renovation of an existing vehicle service module.NOTE: We have already completed SEPA and Site Plan

Review.Project #P-21-0052

On this day we have inspected your construction for **Comment Building Div Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** cancelled by contractor

#### **Corrections:**

- 1 THIS WAS A PRE-FINAL WALK THRU
  - 1. provide report for out side air
  - 2.provide clarification on C/O detection at carwash
  - 3.provide architect drawings for code compliant landing and ramp at parts area as well install
  - 4. provide engineers fix for cmu wall at door in to parts area
  - 5. provide solid grade at side walk and flower beds as discussed with contractor
  - 6. provide accessible table at parts counter
  - 7.complete insulation at circ line at hot water tank
  - 8. provide accessible microwave
  - 9 .provide max ht at mirrors per city approved plans
  - 10. remove lock on door 132 at tech parts as discussed with contractor
  - 11. provide engineering final approval
  - 12. provide fire final approval
  - 13. did not go on roof
  - 14. not a complete list



## City of Puyallup

# **Building Division**

333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590