



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 06, 2023

**Inspection Result:** **PASSED**

**Permit Number:** PRCTI20221876

**Property Address:** 3500 S MERIDIAN, Unit: 966, PUYALLUP, WA 98373;

**Contractor:** JSE CONSTRUCTION LLC 35059 41ST ST PL S AUBURN, WA 98001

**To construct:** Tenant Improvement for Tea Story project involving prep kitchen, sales counter and seating area constructing demising walls and installing hand sink, 3 compartment sink and kitchen equipment's per plans (no kitchen hood, no new restroom) (Occupant load- 22) - 04/20/2023 REVISION (1) - ADDING 2 ADDITIONAL FLOOR SINKS

On this day we have inspected your construction for **Fire Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 Fire Alarm and Fire Sprinkler required in new storage room. Alternative is to cut the wall down 2' and open for heat and smoke detection by neighboring rooms within footage reach.

Sincerely,

David Drake  
Building Inspector II  
DDrake@PuyallupWA.gov  
(253) 864-4171



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)