



City of Puyallup

**Fire Prevention**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 06, 2023

**Inspection Result:** **FAILED**

**Permit Number:** PRFA20230086

**Property Address:** 3500 S MERIDIAN, Unit: 985, PUYALLUP, WA 98373;

**Contractor:** NORTHWEST FIRE SYSTEMS LLC 22645 83RD AVE BLDG D S PUYALLUP, WA 98372

**To construct:** Replace existing fire alarm control panel and addressable devices.  
Currently applying for a UL Certification. 1 FACP and 315 devices.

On this day we have inspected your construction for **Fire Alarm Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 All strobes should be visible in line of site. Add strobes where required by code to be compliant. Storage on racks block strobes. Raise strobes or move to ceiling. Leaving shelves empty for inspection will not be acceptable a permeant solution is required. West fire drop down door does not work as required.

Sincerely,

David Drake  
Building Inspector II  
DDrake@PuyallupWA.gov  
(253) 864-4171