

PRCTI20230877

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic



## ***Structural Calculations***

*PREPARED FOR:*

BOE Architects, PLLC  
1130 Broadway, Suite 207  
Tacoma, WA 98402

*PROJECT:*


Korum Ford EV Court  
DC Charger Foundations  
2230458.20

*PREPARED BY:*

Andrew McEachern, P.E., S.E.  
Principal

*DATE:*

June, 2023



# Structural Calculations

## Korum Ford EV Court

### 100 River Road, Puyallup



Project # 2230458.20

Project Principal

Andrew D. McEachern, P.E., S.E.

## Design Criteria

### Design Codes and Standards

Codes and Standards: Structural design and construction shall be in accordance with the applicable sections of the following codes and standards as adopted and amended by the local building authority: International Building Code, 2018 Edition.

### Structural Design Criteria:

#### Live Load Criteria:

Roof (Min Blanket Snow):	25 psf
Slab on Grade:	125 psf

#### Wind Load Criteria:

Basic Wind Speed:	98 mph
Risk Category:	II
Wind Exposure:	B
Topographic Factor:	1.0

#### Seismic Criteria:

Risk Category:	II
Seismic Importance Factor:	1.0
$S_s = 1.274$	$S_1 = 0.438$
$S_{ds} = 1.019$	$S_{d1} = N/A$
Site Class:	D - default
Seismic Design Category:	D

#### Soil Criteria:

Soil Bearing Capacity: 1,500 psf (assumed). Allow 33% increase for wind or seismic loads.

## Project Description

The structural scope of work for this project involves the structural design of foundations and anchorage for new exterior electric vehicle charging stations. It is the intention of the structural design to satisfy the force levels of the IBC 2018.



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic



CL UNIT AT CL SLAB

8" MIN EDGE DISTANCE TO ANCHORS

EV CHARGER PER PLAN

City of Puyallup Development & Permitting Services ISSUED PERMIT			
Building	Planning	Engineering	Public Works
Fire	Traffic		

4'-0" x 3'-0" x 10" MIN  
CONCRETE PAD AT EA  
EV CHARGER (MIN  
4,000 PSI f'c CONCRETE  
STRENGTH)

4'-0" MIN

3'-0" MIN

CONTRACTOR NOTE:  
PAD THICKNESS MAY  
BE REDUCED TO 8" ABV  
EXISTING EXTERIOR  
WALL STRIP FOOTING

EV CHARGER  
PER PLAN

(4) M16x145 STAINLESS  
STEEL EXP ANCHORS PER  
MFR (5/8" DIA x 5.70")

10" MIN

REINF PAD W/ #5 EA  
WAY AT 12"oc MAX

BACKFILL BENEATH PAD W/  
NON-FROST SUSCEPTIBLE SOILS



2215 North 30th Street, Suite 300  
Tacoma, WA 98403  
253.383.2422 TEL 253.383.2572 FAX

KORUM FORD EV COURT

EV CHARGER FOUNDATION AND ANCHORAGE

DRAWN BY: ADM

DATE: 6/6/2023

JOB NO.: 2230458.20

SSK-01



KORUM FORD SERVICE CTR, 100 RIVER ROAD, PUYALLUP, WA (PARCEL NO. 0420281160)


# EV COURT LAYOUT #5a

BOEarc; 5.05.2023



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic





KORUM FORD E.V. COURT

**STRUCTURAL DETAIL FOR SLAB/FOUNDATION AT CHARGERS**

BOEarc; 6.05.2023




Installation Manual

# Ford Pro™ DC Charging Station 240kW



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

## 2. TECHNICAL CHARACTERISTICS



# 2

Depending on the regulation to be followed, the equipment will fulfill different technical characteristics.

### Standalone NB 240 – IEC / UL


REFERENCE	NB1500H NB1500U NB150SH NB150SU	NB1800H NB1800U NB180SH NB180SU	NB2100H NB2100U NB210SH NB210SU	NB2400H NB2400U NB240SH NB240SU	
DC OUTPUT	Maximum power [kW]	150	180	210	240
	Voltage range [V]	150 – 1000 [1]			
	Available connectors	CCS-1, CCS-2, CHAdeMO			
	Maximum continuous current CCS [A]	300			
	Peak current CCS [A] [2]	500			
	CCS nominal current [A]	Standard: 200. Optional: 250 (only for IEC) or 300			
	Maximum current CHAdeMO [A]	125			
	Maximum number of EVs charging simultaneously	2			
AC OUTPUT (OPTIONAL, ONLY FOR IEC)	Power [kW]	22			
	Voltage range [V]	400 ± 10%			
	Maximum current [A]	32			
	Available connectors	AC Type 2 Socket			
DC OUTPUT FOR ADDITIONAL SATELLITE DISPENSER (OPTIONAL)	Voltage range [V]	-	150 – 1000 [1]		
	Available connectors	-	CCS-1, CCS-2, CHAdeMO		
	CCS connector nominal current [A]	-	Standard: 200. Optional: 250 (only for IEC), 300, 500 (cooled)		
	Peak current CCS [A] [2]	-	500		
	Maximum current CHAdeMO [A]	-	125		
	Number of additional EVs charging simultaneously	-	1	1	2 (slim) / 1 (cooled)
AC INPUT FOR DC OUTPUT	Power [kVA]	158	189	221	253
	Voltage [V]	400 IEC / 480 UL (3ph + N + PE) ± 10%			
	Power factor	> 0.99			
	Frequency [Hz]	50 (IEC) / 60 (IEC & UL)			
	Efficiency	95%			
GENERAL	Interface	10" Touchscreen E-stop pushbutton Credit / debit card reader (optional)			
	RFID reader	ISO14443 A/B, MIFARE, Calypso, ISO18092, ISO15693 and more			
	Protections	Isolation monitor Surge arrester Type 2 (optional) DC Charge: RCD Type A (optional) + MCB AC charge (optional): MCB + RCD Type A + RCM			
	Others	Smart Fleet Management (optional) Smart Power Balance (optional)			




REFERENCE	NB1500H NB1500U NB150SH NB150SU	NB1800H NB1800U NB180SH NB180SU	NB2100H NB2100U NB210SH NB210SU	NB2400H NB2400U NB240SH NB240SU
GENERAL	Internal DC energy measurement			
	Energy meter	DC meter for DC output (optional)		
		AC MID meter for AC output		
	Cable length [m/ft]	5 / 16.4 with cable management system (optionally, 7.6 / 25)		
	Enclosure / foot / glass color	White (RAL 9016) / Grey (RAL 7016) / Black		
	Customization [3]	Enclosure / Foot / Glass / Logo / Display		
	Protection rating	NEMA 3R   IP54   IK10 (IK08 for ventilation grilles)		
	Operating temperature range [°C/°F]	-30 to 50 / -22 to 122		
	Relative humidity	From 4% to 95%		
	Maximum altitude above sea [m/ft]	Without derating: 2000 / 6561. Max: 3000 / 9842		
	Communications	Ethernet (10/100) + Wi-Fi		
		Cellular data: 4G, 3G, GSM		
	Charge protocols	Autocharge, ISO 15118, CHAdeMO, IEC 61851, OCPP 1.6J, DIN 70121		
	Dimensions (WxDxH) [mm/ft]	670 x 950 x 2000 / 2.19 x 3.12 x 6.56		
Regulation	IEC 61851-1, IEC 61851-20, IEC 61851-24, IEC 61851-24-2 UL 2202, NEC 625, FCC Part 15 Class A			

- Notes:** [1] 150 - 500 Vdc for CHAdeMO. Maximum power from 300 V.  
 [2] Consult with Power Electronics for more information about the connector overload capability.  
 [3] Consult with Power Electronics for further information.

Be aware that Power Electronics is not responsible for the charger's input power connection, nor its installation.




# 3.DIMENSIONS AND WEIGHT



The dimensions, gravity center and the weight of the **NB 240** equipment are detailed in this section.

The right and front view, from left to right, are shown below:




NB240DTD001A

GENERAL DIMENSIONS										
	A	B	C	D	E	F	G	H	I	J
mm	35	2000	1900	100	850	950	956	340	670	798
in.	1.38	78.74	74.80	3.94	33.46	37.40	37.64	13.39	26.39	31.42

**Note:** The bottom-up view is shown in the "[Anchoring of the equipment](#)" and "[Access](#)" section of this document.

The front and left view, from left to right, are shown below:



NB240DTD004A


GRAVITY CENTER			
	X	Y	Z
mm	963	346	449,5
in.	37.92	13.62	17.70

The approximate weight for the NB 240 is 600 kg (1322.77 lb)<sup>1</sup>.

<sup>1</sup> For other equipment of the NB 240 range, consult Power Electronics.

# 5. PREPARATION FOR INSTALLING THE EQUIPMENT

## 5



### Site recommendations

When deciding the location of the equipment and planning its installation, it is recommended to follow a series of guidelines derived from its characteristics.



#### CAUTION

**To guarantee proper electrical installation, it is very important to comply with the bend radius of the cable.** The customer must ensure the cables enter the equipment perpendicularly and the spacing between them is appropriate.

**Avoid corrosive environments that may affect the equipment's proper functioning.**



#### NOTICE

**The instructions given in this section must not replace in any way the mandatory regulations of the country in which the equipment will be installed.**

**Prior to installation, a geotechnical study of the terrain where the equipment will be installed must be carried out to determine its characteristics and to decide the most suitable type of foundation.**


**It is the customer's responsibility to design and build concrete foundations with the necessary piping and ground network in accordance with the applicable regulatory requirements.**

**Proper installation is absolutely necessary, and it is not within the scope of the manufacturer's responsibility.**

### Soil

The soil should have the following characteristics:

- It must be dry, compacted, stable and homogeneous.
- The land will be gravel, ballast, or pebble.
- It must have hard or medium harshness characteristics.
- The calculation of the maximum permissible pressure on the ground must comply with local and national standards, as well as with any other requirements regarding natural disasters (hurricanes, earthquakes, etc.) that may apply to the place of installation.
- Do not install on floodplains.
- The soil must be provided with a drainage system, especially in locations with high water tables and / or heavy precipitation sites.
- It is recommended that the ground should not exceed the level of the foundation.
- Soil compaction degree of 98 %.
- Maximum slope is 0,25 %.
- It must not be a direct place of passage so that the load cables do not interrupt the movement of pedestrians or traffic.



## Site basis

Power Electronics recommends making a concrete foundation slab to support the charger. **The support surface for the equipment must be perfectly level. The client is responsible for the correct dimensioning and construction of the foundation in accordance with current regulations.** The foundation must meet the following characteristics:

- It is recommended that a layer of cleaning concrete be installed between the ground and the foundation.
- The sizing should be appropriate for the weight of the equipment and the characteristics of the soil
- It must be thick enough to support the equipment.
- It must have trenches wide enough to ensure proper wiring passage (the suggested cable access size is shown below).
- It is advisable to leave the slab at the same level as the ground to facilitate maintenance works.
- If the slab is above ground level, the maximum height allowed is 200 m (7.87 in.).

## NOTICE

---

**The client is responsible for building a solid concrete base perfectly leveled and elevated with respect to the user's floor height.**

---

**The equipment is not designed for mobile installations.** In case of installing the equipment over a mobile platform, the warranty may be voided. For further information on this kind of applications, please contact Power Electronics.

---

In case of specification of variable actions such as snow, wind or earthquake, the slab must comply with the following requirements, **not being excluding those indicated by the specific regulations of the country of installation:**

- Ability to withstand compression forces of 25 N/mm<sup>2</sup>. ↖ 3,625 psi
- Steel reinforcement capable of withstanding tensile forces of 500 N/mm<sup>2</sup>. ↖ 72,519 psi
- Taking into account severe wind conditions (60 m/s), the reinforcement should be dimensioned as follows:
  - The longitudinal side of the reinforcement must be able to withstand forces of up to 80 kN. ↖ 134 mph
  - The transverse side of the reinforcement must be able to withstand forces of up to 10 kN. ↖ 17,985 lbs  
↖ 2,248 lbs

**Note that the thickness of the slab must be determined from the results of the geotechnical study.**


See anchor recommendations at the "[Anchoring of the equipment](#)" section.

## NOTICE

---

Each charger must be anchored to a foundation which guarantees its stability towards vertical and horizontal actions. **It is customer's responsibility to design and build the foundation to guarantee stability of each equipment.**

---




# Anchoring of the equipment

## NOTICE

**It is the customer's responsibility to dimension correctly posts anchoring to the foundation, guaranteeing stability towards horizontal actions.**

The equipment must be anchored to a solid and leveled surface (slab), see slab recommendations at the "Site basis" section.

The following image (bottom-up view) shows the location and diameter of the charger's anchoring holes. They are located at the foot of the charger.



GENERAL DIMENSIONS

	A	B	C	D	E	F	G	H	Ø
mm	10	40	52,5	340	235	682	760	850	20
in.	0.40	1.57	2.07	13.39	9.25	26.85	29.92	33.46	0.79

APPROXIMATELY 5/8" DIA x 5.70" EXP ANCHORS

It is recommended to use an expansive anchoring M16x145, with a tightening torque of 120 Nm (manufacturer's recommendation). To guarantee the proper fixing of the equipment, install a total of 4 anchors.



# ASCE 7 Hazards Report

City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic

**Address:**  
100 River Rd  
Puyallup, Washington  
98371

**Standard:** ASCE/SEI 7-16  
**Risk Category:** II  
**Soil Class:** D - Default (see Section 11.4.3)

**Latitude:** 47.198106  
**Longitude:** -122.294367  
**Elevation:** 43.09182229757344 ft (NAVD 88)



## Wind

### Results:


Wind Speed	98 Vmph
10-year MRI	67 Vmph
25-year MRI	73 Vmph
50-year MRI	78 Vmph
100-year MRI	83 Vmph

Data Source: ASCE/SEI 7-16, Fig. 26.5-1B and Figs. CC.2-1–CC.2-4, and Section 26.5.2

Date Accessed: Tue Jun 06 2023

Value provided is 3-second gust wind speeds at 33 ft above ground for Exposure C Category, based on linear interpolation between contours. Wind speeds are interpolated in accordance with the 7-16 Standard. Wind speeds correspond to approximately a 7% probability of exceedance in 50 years (annual exceedance probability = 0.00143, MRI = 700 years).

Site is not in a hurricane-prone region as defined in ASCE/SEI 7-16 Section 26.2.



**Site Soil Class:** D - Default (see Section 11.4.3)

**Results:**

$S_s$ :	1.274	$S_{D1}$ :	N/A
$S_1$ :	0.438	$T_L$ :	6
$F_a$ :	1.2	PGA :	0.5
$F_v$ :	N/A	PGA <sub>M</sub> :	0.6
$S_{MS}$ :	1.529	$F_{PGA}$ :	1.2
$S_{M1}$ :	N/A	$I_e$ :	1
$S_{DS}$ :	1.019	$C_v$ :	1.355

Ground motion hazard analysis may be required. See ASCE/SEI 7-16 Section 11.4.8.

**Data Accessed:** Tue Jun 06 2023

**Date Source:** [USGS Seismic Design Maps](#)




The ASCE 7 Hazard Tool is provided for your convenience, for informational purposes only, and is provided “as is” and without warranties of any kind. The location data included herein has been obtained from information developed, produced, and maintained by third party providers; or has been extrapolated from maps incorporated in the ASCE 7 standard. While ASCE has made every effort to use data obtained from reliable sources or methodologies, ASCE does not make any representations or warranties as to the accuracy, completeness, reliability, currency, or quality of any data provided herein. Any third-party links provided by this Tool should not be construed as an endorsement, affiliation, relationship, or sponsorship of such third-party content by or from ASCE.

ASCE does not intend, nor should anyone interpret, the results provided by this Tool to replace the sound judgment of a competent professional, having knowledge and experience in the appropriate field(s) of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the contents of this Tool or the ASCE 7 standard.

In using this Tool, you expressly assume all risks associated with your use. Under no circumstances shall ASCE or its officers, directors, employees, members, affiliates, or agents be liable to you or any other person for any direct, indirect, special, incidental, or consequential damages arising from or related to your use of, or reliance on, the Tool or any information obtained therein. To the fullest extent permitted by law, you agree to release and hold harmless ASCE from any and all liability of any nature arising out of or resulting from any use of data provided by the ASCE 7 Hazard Tool.

**AHBL Inc.**  
 2215 N. 30th St.  
 Tacoma, WA 98403  
 253-383-2422



JOB TITLE Korum Ford EV Court

JOB NO. 2230458.20 SHEET NO. \_\_\_\_\_

CALCULATED BY \_\_\_\_\_ DATE \_\_\_\_\_

CHECKED BY ADM DATE 6/6/23

**Wind Loads - Other Structures:**

ASCE 7- 16

Ultimate Wind Pressures

Wind Factor = 1.00  
 Gust Effect Factor (G) = 0.85 Ultimate Wind Speed = 98 mph  
 Kzt = 1.00 Exposure = B

**A. Solid Freestanding Walls & Solid Signs (& open signs with less than 30% open)**

Dist to sign top (h)	7.0 ft	s/h =	0.93	<b><u>Case A &amp; B</u></b>	
Height (s)	6.5 ft	B/s =	0.50	C <sub>f</sub> = 1.59	
Width (B)	3.3 ft	Lr/s =	0.00	F = qz G C <sub>f</sub> A <sub>s</sub> = <b>16.2 As</b>	
Wall Return (Lr) =		Kz =	0.575	A <sub>s</sub> = 22.0 sf	
Directionality (Kd)	0.85	qz =	12.0 psf	F = 356 lbs	
Percent of open area to gross area	0.0%	Open reduction factor =	1.00	<b><u>CaseC</u></b>	
		<b><u>Case C reduction factors</u></b>		Horiz dist from windward edge	
		Factor if s/h>0.8 =	0.87	0 to s	C <sub>f</sub> = 1.96 F=qzGCfAs (psf) = 20.0 <b>As</b>
		Wall return factor for C <sub>f</sub> at 0 to s =	1.00	s to 2s	C <sub>f</sub> = 1.31 F=qzGCfAs (psf) = 16.0 <b>As</b>


Project KORUN EV  
 Subject \_\_\_\_\_  
 With/To \_\_\_\_\_  
 Address \_\_\_\_\_  
 Date 6/6/23

Project No. 2230458.20  
 Phone \_\_\_\_\_  
 Fax # \_\_\_\_\_  
 # Faxed Pages \_\_\_\_\_  
 By ADM

- Page \_\_\_\_\_ of \_\_\_\_\_
- Calculations
- Fax
- Memorandum
- Meeting Minutes
- Telephone Memo



Civil Engineers  
 Structural Engineers  
 Landscape Architects  
 Community Planners  
 Land Surveyors



SEISMIC LOADS

PER ASCE 7-16 SECTION 13.3

$$F_p = \frac{0.4 a_p S_{DS} W_p}{(R_p / I_p)} (1 + 2 z/h)$$

$$= \frac{0.4 (1.0) (1.019) W_p}{(2.5 / 1.0)} (1 + 2(0))$$

$$= 0.163 W_p$$

GIVEN  
 $a_p = 1.0$   
 $R_p = 2.5$   
 $I_p = 1.0$   
 $z/h = 0.0$   
 $S_{DS} = 1.019$

$$F_{pmin} = 0.3 S_{DS} I_p W_p$$

$$= 0.3 (1.019) (1.0) W_p$$


$$= 0.3057 W_p$$

∴ USE 0.31 Wp

Project KORUM EV  
 Subject \_\_\_\_\_  
 With/To \_\_\_\_\_  
 Address \_\_\_\_\_  
 Date 6/6/23

Project No. 2230498.20  
 Phone \_\_\_\_\_  
 Fax # \_\_\_\_\_  
 # Faxed Pages \_\_\_\_\_  
 By ADM


- Page \_\_\_\_\_ of \_\_\_\_\_
- Calculations
- Fax
- Memorandum
- Meeting Minutes
- Telephone Memo



EQUIPMENT ANCHORAGE

REVIEW LOADING IN TRANSVERSE DIRECTION ONLY (CONTROLS BY INSPECTION)

Civil Engineers  
 Structural Engineers  
 Landscape Architects  
 Community Planners  
 Land Surveyors



$EQ = 0.31 WP$   
 $= 420 \# ULT$

$W = 16.2 ppsf (38") (79")$

$= 16.2 ppsf (2150)$

$= 340 \# ULT$

MAX SHEAR

$V = 420 \# ULT = 294 \# ASD$

MAX MOMENT


$M_{EQ} = 420 \# (38")$   
 $= 1.33 k \cdot ft ULT$

$M_W = 16.2 ppsf (38") (79") (79"/2)$   
 $= 1.1 k \cdot ft ULT$

$\therefore$  USE 1.33 k·ft ULT / 0.93 k·ft ASD



AHBL Engineers  
2215 North 30th Street  
Suite 300  
Tacoma, WA 98403  
253.383.2422



Project Title: Korum Ford EV Court  
Engineer: ADM  
Project ID: 2230458.20  
Project Descr: Foundation for Exterior EV Charging Station

## General Footing

Project File: 2230458.ec6

LIC#: KW-06014847, Build: 20.23.04.05

AHBL, INC

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** EV Foundation

### Code References

Calculations per ACI 318-14, IBC 2018, CBC 2019, ASCE 7-16  
Load Combinations Used : IBC 2018

### General Information

#### Material Properties

$f_c$ : Concrete 28 day strength	=	3.0 ksi
$f_y$ : Rebar Yield	=	60.0 ksi
$E_c$ : Concrete Elastic Modulus	=	3,122.0 ksi
Concrete Density	=	145.0 pcf
$\phi$ Values Flexure	=	0.90
Shear	=	0.750

#### Analysis Settings

Min Steel % Bending Reinf.	=	
Min Allow % Temp Reinf.	=	0.00180
Min. Overturning Safety Factor	=	1.0 : 1
Min. Sliding Safety Factor	=	1.0 : 1
Add Ftg Wt for Soil Pressure	:	Yes
Use ftg wt for stability, moments & shears	:	Yes
Add Pedestal Wt for Soil Pressure	:	No
Use Pedestal wt for stability, mom & shear	:	No

#### Soil Design Values

Allowable Soil Bearing	=	1.50 ksf
Soil Density	=	110.0 pcf
Increase Bearing By Footing Weight	=	No
Soil Passive Resistance (for Sliding)	=	250.0 pcf
Soil/Concrete Friction Coeff.	=	0.30

#### Increases based on footing depth

Footing base depth below soil surface	=	0.670 ft
Allow press. increase per foot of depth when footing base is below	=	ksf ft


#### Increases based on footing plan dimension

Allowable pressure increase per foot of depth when max. length or width is greater than	=	ksf ft
---	---	--------

### Dimensions

Width parallel to X-X Axis	=	3.0 ft
Length parallel to Z-Z Axis	=	3.0 ft
Footing Thickness	=	8.0 in

Pedestal dimensions...		
px : parallel to X-X Axis	"	10.0 in
pz : parallel to Z-Z Axis	"	30.0 in
Height	"	6.0 in
Rebar Centerline to Edge of Concrete... at Bottom of footing	"	4.0 in




### Reinforcing

Bars parallel to X-X Axis	=	
Number of Bars	=	4
Reinforcing Bar Size	=	# 4
Bars parallel to Z-Z Axis	=	
Number of Bars	=	4
Reinforcing Bar Size	=	# 4

#### Bandwidth Distribution Check (ACI 15.4.4.2)

Direction Requiring Closer Separation		n/a
# Bars required within zone		n/a
# Bars required on each side of zone		n/a




### Applied Loads

	D	Lr	L	S	W	E	H
P : Column Load	=	1.40			0.0		k
OB : Overburden	=						ksf
M-xx	=						k-ft
M-zz	=				1.10	1.40	k-ft
V-x	=				0.340	0.420	k
V-z	=						k



AHBL Engineers  
2215 North 30th Street  
Suite 300  
Tacoma, WA 98403  
253.383.2422



Project Title: Korum Ford EV Court  
Engineer: ADM  
Project ID: 2230458.20  
Project Descr: Foundation for Exterior EV Charging Station

**General Footing**

Project File: 2230458.ec6

LIC#: KW-06014847, Build:20.23.04.05

AHBL, INC

(c) ENERCALC INC 1983-2023

**DESCRIPTION: EV Foundation**

**DESIGN SUMMARY**

**Design OK**

	Min. Ratio	Item	Applied	Capacity	Governing Load Combination
PASS	0.3777	Soil Bearing	0.5666 ksf	1.50 ksf	+0.60D+0.70E about Z-Z axis
PASS	n/a	Overturing - X-X	0.0 k-ft	0.0 k-ft	No Overturing
PASS	1.546	Overturing - Z-Z	1.323 k-ft	2.045 k-ft	+0.60D+0.70E
PASS	1.964	Sliding - X-X	0.2940 k	0.5774 k	+0.60D+0.70E
PASS	n/a	Sliding - Z-Z	0.0 k	0.0 k	No Sliding
PASS	n/a	Uplift	0.0 k	0.0 k	No Uplift
PASS	0.07022	Z Flexure (+X)	0.3150 k-ft/ft	4.486 k-ft/ft	+0.90D+E
PASS	0.02847	Z Flexure (-X)	0.1277 k-ft/ft	4.486 k-ft/ft	+1.40D
PASS	0.001514	X Flexure (+Z)	0.006791 k-ft/ft	4.486 k-ft/ft	+1.40D
PASS	0.001514	X Flexure (-Z)	0.006791 k-ft/ft	4.486 k-ft/ft	+1.40D
PASS	0.1009	1-way Shear (+X)	8.290 psi	82.158 psi	+0.90D+E
PASS	0.04140	1-way Shear (-X)	3.401 psi	82.158 psi	+1.40D
PASS	n/a	1-way Shear (+Z)	0.0 psi	82.158 psi	n/a
PASS	n/a	1-way Shear (-Z)	0.0 psi	82.158 psi	n/a
PASS	0.02395	2-way Punching	3.279 psi	136.931 psi	+1.40D

**Detailed Results**

**Soil Bearing**


Rotation Axis & Load Combination...	Gross Allowable	Xeccc	Zeccc (in)	Actual Soil Bearing Stress @ Location				Actual / Allow Ratio
				Bottom, -Z	Top, +Z	Left, -X	Right, +X	
X-X, D Only	1.50	n/a	0.0	0.2525	0.2525	n/a	n/a	0.168
X-X, +D+0.60W	1.50	n/a	0.0	0.2525	0.2525	n/a	n/a	0.168
X-X, +D+0.70E	1.50	n/a	0.0	0.2525	0.2525	n/a	n/a	0.168
X-X, +D+0.450W	1.50	n/a	0.0	0.2525	0.2525	n/a	n/a	0.168
X-X, +D+0.5250E	1.50	n/a	0.0	0.2525	0.2525	n/a	n/a	0.168
X-X, +0.60D+0.60W	1.50	n/a	0.0	0.1515	0.1515	n/a	n/a	0.101
X-X, +0.60D+0.70E	1.50	n/a	0.0	0.1515	0.1515	n/a	n/a	0.101
Z-Z, D Only	1.50	0.0	n/a	n/a	n/a	0.2525	0.2525	0.168
Z-Z, +D+0.60W	1.50	4.742	n/a	n/a	n/a	0.05494	0.4501	0.300
Z-Z, +D+0.70E	1.50	6.986	n/a	n/a	n/a	0.0	0.5472	0.365
Z-Z, +D+0.450W	1.50	3.556	n/a	n/a	n/a	0.1043	0.4007	0.267
Z-Z, +D+0.5250E	1.50	5.240	n/a	n/a	n/a	0.03421	0.4708	0.314
Z-Z, +0.60D+0.60W	1.50	7.903	n/a	n/a	n/a	0.0	0.3580	0.239
Z-Z, +0.60D+0.70E	1.50	11.643	n/a	n/a	n/a	0.0	0.5666	0.378

**Overturing Stability**

Rotation Axis & Load Combination...	Overturing Moment	Resisting Moment	Stability Ratio	Status
X-X, D Only	None	0.0 k-ft	Infinity	OK
X-X, +D+0.60W	None	0.0 k-ft	Infinity	OK
X-X, +D+0.70E	None	0.0 k-ft	Infinity	OK
X-X, +D+0.450W	None	0.0 k-ft	Infinity	OK
X-X, +D+0.5250E	None	0.0 k-ft	Infinity	OK
X-X, +0.60D+0.60W	None	0.0 k-ft	Infinity	OK
X-X, +0.60D+0.70E	None	0.0 k-ft	Infinity	OK
Z-Z, D Only	None	0.0 k-ft	Infinity	OK
Z-Z, +D+0.60W	0.8980 k-ft	3.409 k-ft	3.796	OK
Z-Z, +D+0.70E	1.323 k-ft	3.409 k-ft	2.577	OK
Z-Z, +D+0.450W	0.6735 k-ft	3.409 k-ft	5.061	OK
Z-Z, +D+0.5250E	0.9923 k-ft	3.409 k-ft	3.435	OK
Z-Z, +0.60D+0.60W	0.8980 k-ft	2.045 k-ft	2.278	OK
Z-Z, +0.60D+0.70E	1.323 k-ft	2.045 k-ft	1.546	OK



AHBL Engineers  
 2215 North 30th Street  
 Suite 300  
 Tacoma, WA 98403  
 253.383.2422



Project Title: Korum Ford EV Court  
 Engineer: ADM  
 Project ID: 2230458.20  
 Project Descr: Foundation for Exterior EV Charging Station

**General Footing**

Project File: 2230458.ec6

LIC# : KW-06014847, Build:20.23.04.05

AHBL, INC

(c) ENERCALC INC 1983-2023

**DESCRIPTION: EV Foundation**

All units k

**Sliding Stability**

Force Application Axis Load Combination...	Sliding Force	Resisting Force	Stability Ratio	Status
X-X, D Only	0.0 k	0.8501 k	No Sliding	OK
X-X, +D+0.60W	0.2040 k	0.8501 k	4.167	OK
X-X, +D+0.70E	0.2940 k	0.8501 k	2.891	OK
X-X, +D+0.450W	0.1530 k	0.8501 k	5.556	OK
X-X, +D+0.5250E	0.2205 k	0.8501 k	3.855	OK
X-X, +0.60D+0.60W	0.2040 k	0.5774 k	2.830	OK
X-X, +0.60D+0.70E	0.2940 k	0.5774 k	1.964	OK
Z-Z, D Only	0.0 k	0.8501 k	No Sliding	OK
Z-Z, +D+0.60W	0.0 k	0.8501 k	No Sliding	OK
Z-Z, +D+0.70E	0.0 k	0.8501 k	No Sliding	OK
Z-Z, +D+0.450W	0.0 k	0.8501 k	No Sliding	OK
Z-Z, +D+0.5250E	0.0 k	0.8501 k	No Sliding	OK
Z-Z, +0.60D+0.60W	0.0 k	0.5774 k	No Sliding	OK
Z-Z, +0.60D+0.70E	0.0 k	0.5774 k	No Sliding	OK

**Footing Flexure**

Flexure Axis & Load Combination	Mu k-ft	Side	Tension Surface	As Req'd in^2	Gvrn. As in^2	Actual As in^2	Phi*Mn k-ft	Status
X-X, +1.40D	0.006791	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.40D	0.006791	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D	0.005821	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D	0.005821	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+0.50W	0.005821	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+0.50W	0.005821	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+W	0.005821	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+W	0.005821	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+E	0.005821	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +1.20D+E	0.005821	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +0.90D+W	0.004366	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +0.90D+W	0.004366	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +0.90D+E	0.004366	+Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
X-X, +0.90D+E	0.004366	-Z	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.40D	0.1277	-X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.40D	0.1277	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D	0.1095	-X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D	0.1095	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D+0.50W	0.03539	-X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D+0.50W	0.1836	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D+W	0.03772	-X	Top	0.1728	AsMin	0.2667	5.686	OK
Z-Z, +1.20D+W	0.2582	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +1.20D+E	0.06170	-X	Top	0.1728	AsMin	0.2667	5.686	OK
Z-Z, +1.20D+E	0.3066	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +0.90D+W	0.04874	-X	Top	0.1728	AsMin	0.2667	5.686	OK
Z-Z, +0.90D+W	0.2415	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK
Z-Z, +0.90D+E	0.05125	-X	Top	0.1728	AsMin	0.2667	5.686	OK
Z-Z, +0.90D+E	0.3150	+X	Bottom	0.1728	AsMin	0.2667	4.486	OK

**One Way Shear**

Load Combination...	Vu @ -X	Vu @ +X	Vu @ -Z	Vu @ +Z	Vu:Max	Phi Vn	Vu / Phi*Vn	Status
+1.40D	3.40 psi	3.40 psi	0.00 psi	0.00 psi	3.40 psi	82.16 psi	0.04	OK
+1.20D	2.92 psi	2.92 psi	0.00 psi	0.00 psi	2.92 psi	82.16 psi	0.04	OK
+1.20D+0.50W	0.97 psi	4.86 psi	0.00 psi	0.00 psi	4.86 psi	82.16 psi	0.06	OK
+1.20D+W	0.97 psi	6.83 psi	0.00 psi	0.00 psi	6.83 psi	82.16 psi	0.08	OK
+1.20D+E	1.73 psi	8.10 psi	0.00 psi	0.00 psi	8.10 psi	82.16 psi	0.10	OK
+0.90D+W	1.36 psi	6.38 psi	0.00 psi	0.00 psi	6.38 psi	82.16 psi	0.08	OK
+0.90D+E	1.37 psi	8.29 psi	0.00 psi	0.00 psi	8.29 psi	82.16 psi	0.10	OK


**Two-Way "Punching" Shear**

All units k

Load Combination...	Vu	Phi*Vn	Vu / Phi*Vn	Status
+1.40D	3.28 psi	136.93psi	0.02395	OK
+1.20D	2.81 psi	136.93psi	0.02053	OK
+1.20D+0.50W	2.81 psi	136.93psi	0.02053	OK



AHBL Engineers  
 2215 North 30th Street  
 Suite 300  
 Tacoma, WA 98403  
 253.383.2422



Project Title: Korum Ford EV Court  
 Engineer: ADM  
 Project ID: 2230458.20  
 Project Descr: Foundation for Exterior EV Charging Station

**General Footing**

Project File: 2230458.ec6

LIC# : KW-06014847, Build:20.23.04.05

AHBL, INC

(c) ENERCALC INC 1983-2023

**DESCRIPTION:** EV Foundation

**Two-Way "Punching" Shear**

All units k

Load Combination...	Vu	Phi*Vn	Vu / Phi*Vn	Status
+1.20D+W	2.82 psi	136.93psi	0.02057	OK
+1.20D+E	2.85 psi	136.93psi	0.02078	OK
+0.90D+W	2.14 psi	136.93psi	0.01564	OK
+0.90D+E	2.19 psi	136.93psi	0.01601	OK






Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	1/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		

### 1. Project information

Customer company:  
Customer contact name:  
Customer e-mail:  
Comment: Seismic forces have been increased by overstrength factor (2.0) per ACI.

Project description: Anchorage of EV Chargers  
Location:  
Fastening description:



### 2. Input Data & Anchor Parameters

#### General

Design method: ACI 318-19  
Units: Imperial units

#### Anchor Information:

Anchor type: Torque controlled expansion anchor  
Material: Carbon Steel  
Diameter (inch): 0.625  
Nominal Embedment depth (inch): 5.125  
Effective Embedment depth,  $h_{ef}$  (inch): 4.500  
Code report: ICC-ES ESR-3037  
Anchor category: 1  
Anchor ductility: Yes  
 $h_{min}$  (inch): 7.88  
 $c_{ac}$  (inch): 9.00  
 $c_{min}$  (inch): 8.00  
 $s_{min}$  (inch): 2.75

#### Base Material

Concrete: Normal-weight  
Concrete thickness,  $h$  (inch): 8.00  
State: Cracked  
Compressive strength,  $f_c$  (psi): 3000  
 $\Psi_{e,v}$ : 1.0  
Reinforcement condition: Supplementary reinforcement not present  
Supplemental edge reinforcement: Not applicable  
Reinforcement provided at corners: No  
Ignore concrete breakout in tension: No  
Ignore concrete breakout in shear: No  
Ignore 6do requirement: Not applicable  
Build-up grout pad: No

#### Base Plate

Length x Width x Thickness (inch): 33.50 x 13.25 x 0.25

#### Recommended Anchor

Anchor Name: Strong-Bolt® 2 - 5/8"Ø CS Strong-Bolt 2,  $h_{nom}$ : 5.125" (130mm)  
Code Report: ICC-ES ESR-3037





Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	2/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		

**Load and Geometry**


Load factor source: ACI 318 Section 5.3  
 Load combination: not set  
 Seismic design: Yes  
 Anchors subjected to sustained tension: Not applicable  
 Ductility section for tension: 17.10.5.3 (d) is satisfied  
 Ductility section for shear: 17.10.6.3 (c) is satisfied  
 $\Omega_0$  factor: not set  
 Apply entire shear load at front row: No  
 Anchors only resisting wind and/or seismic loads: Yes

City of Puyallup Development & Permitting Services ISSUED PERMIT			
Building	Planning	Engineering	Public Works
Fire	Traffic		

Strength level loads:

$N_{ua}$  [lb]: 0  
 $V_{uax}$  [lb]: 0  
 $V_{uay}$  [lb]: 840  
 $M_{ux}$  [ft-lb]: -2660  
 $M_{uy}$  [ft-lb]: 0  
 $M_{uz}$  [ft-lb]: 0

<Figure 1>




Input data and results must be checked for agreement with the existing circumstances, the standards and guidelines must be checked for plausibility.



Anchor Designer™  
Software  
Version 3.1.2209.3

Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	3/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		

<Figure 2>



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire	Traffic





Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	4/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		

### 3. Resulting Anchor Forces

Anchor	Tension load, $N_{ua}$ (lb)	Shear load x, $V_{uax}$ (lb)	Shear load y, $V_{uay}$ (lb)	Shear load combined, $\sqrt{(V_{uax})^2 + (V_{uay})^2}$ (lb)
1	1466.6	0.0	210.0	210.0
2	90.9	0.0	210.0	210.0
3	90.9	0.0	210.0	210.0
4	1466.6	0.0	210.0	210.0
Sum	3115.0	0.0	840.0	840.0

Maximum concrete compression strain (%): 0.03  
 Maximum concrete compression stress (psi): 134  
 Resultant tension force (lb): 3115  
 Resultant compression force (lb): 3115  
 Eccentricity of resultant tension forces in x-axis,  $e'_{Nx}$  (inch): 4.08  
 Eccentricity of resultant tension forces in y-axis,  $e'_{Ny}$  (inch): 0.00  
 Eccentricity of resultant shear forces in x-axis,  $e'_{Vx}$  (inch): 0.00  
 Eccentricity of resultant shear forces in y-axis,  $e'_{Vy}$  (inch): 0.00

<Figure 3>



### 4. Steel Strength of Anchor in Tension (Sec. 17.6.1)

$N_{sa}$ (lb)	$\phi$	$\phi N_{sa}$ (lb)
19070	0.75	14303

### 5. Concrete Breakout Strength of Anchor in Tension (Sec. 17.6.2)

$$N_b = k_c \lambda_a \sqrt{f_c} h_{ef}^{1.5} \text{ (Eq. 17.6.2.2.1)}$$

$k_c$	$\lambda_a$	$f_c$ (psi)	$h_{ef}$ (in)	$N_b$ (lb)
17.0	1.00	3000	4.500	8888

$$0.75 \phi N_{cbg} = 0.75 \phi (A_{Nc} / A_{Nco}) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \text{ (Sec. 17.5.1.2 \& Eq. 17.6.2.1a)}$$

$A_{Nc}$ (in <sup>2</sup> )	$A_{Nco}$ (in <sup>2</sup> )	$C_{a,min}$ (in)	$\psi_{ec,N}$	$\psi_{ed,N}$	$\psi_{c,N}$	$\psi_{cp,N}$	$N_b$ (lb)	$\phi$	$0.75 \phi N_{cbg}$ (lb)
614.25	182.25	9.00	0.623	1.000	1.00	1.000	8888	0.65	9098

### 6. Pullout Strength of Anchor in Tension (Sec. 17.6.3)


$$0.75 \phi N_{pn} = 0.75 \phi \psi_{c,P} \lambda_a N_p (f_c / 2,500)^n \text{ (Sec. 17.5.1.2, Eq. 17.6.3.1 \& Code Report)}$$

$\psi_{c,P}$	$\lambda_a$	$N_p$ (lb)	$f_c$ (psi)	$n$	$\phi$	$0.75 \phi N_{pn}$ (lb)
1.0	1.00	6895	3000	0.50	0.65	3682



Anchor Designer™  
Software  
Version 3.1.2209.3

Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	5/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		



**8. Steel Strength of Anchor in Shear (Sec. 17.7.1)**

$V_{sa}$ (lb)	$\phi_{grout}$	$\phi$	$\phi_{grout}\phi V_{sa}$ (lb)
9930	1.0	0.65	6455

**9. Concrete Breakout Strength of Anchor in Shear (Sec. 17.7.2)**

Shear perpendicular to edge in y-direction:

$$V_{by} = \min|7(l_e / d_a)^{0.2} \sqrt{d_a} \lambda_a \sqrt{f_c} c_{a1}^{1.5}; 9 \lambda_a \sqrt{f_c} c_{a1}^{1.5}| \text{ (Eq. 17.7.2.2.1a \& Eq. 17.7.2.2.1b)}$$

$l_e$ (in)	$d_a$ (in)	$\lambda_a$	$f_c$ (psi)	$c_{a1}$ (in)	$V_{by}$ (lb)
4.50	0.625	1.00	3000	10.00	14225

$$\phi V_{cbgy} = \phi (A_{Vc} / A_{Vco}) \psi_{ec,v} \psi_{ed,v} \psi_{c,v} \psi_{h,v} V_{by} \text{ (Sec. 17.5.1.2 \& Eq. 17.7.2.1b)}$$

$A_{Vc}$ (in <sup>2</sup> )	$A_{Vco}$ (in <sup>2</sup> )	$\psi_{ec,v}$	$\psi_{ed,v}$	$\psi_{c,v}$	$\psi_{h,v}$	$V_{by}$ (lb)	$\phi$	$\phi V_{cbgy}$ (lb)
384.00	450.00	1.000	0.880	1.000	1.369	14225	0.70	10239

Shear parallel to edge in x-direction:

$$V_{by} = \min|7(l_e / d_a)^{0.2} \sqrt{d_a} \lambda_a \sqrt{f_c} c_{a1}^{1.5}; 9 \lambda_a \sqrt{f_c} c_{a1}^{1.5}| \text{ (Eq. 17.7.2.2.1a \& Eq. 17.7.2.2.1b)}$$

$l_e$ (in)	$d_a$ (in)	$\lambda_a$	$f_c$ (psi)	$c_{a1}$ (in)	$V_{by}$ (lb)
4.50	0.625	1.00	3000	8.00	10179

$$\phi V_{cbgx} = \phi (2)(A_{Vc} / A_{Vco}) \psi_{ec,v} \psi_{ed,v} \psi_{c,v} \psi_{h,v} V_{by} \text{ (Sec. 17.5.1.2, 17.7.2.1(c) \& Eq. 17.7.2.1b)}$$

$A_{Vc}$ (in <sup>2</sup> )	$A_{Vco}$ (in <sup>2</sup> )	$\psi_{ec,v}$	$\psi_{ed,v}$	$\psi_{c,v}$	$\psi_{h,v}$	$V_{by}$ (lb)	$\phi$	$\phi V_{cbgx}$ (lb)
266.00	288.00	1.000	1.000	1.000	1.225	10179	0.70	16120

**10. Concrete Pryout Strength of Anchor in Shear (Sec. 17.7.3)**

$$\phi V_{cpg} = \phi K_{cp} N_{cbg} = \phi K_{cp} (A_{Nc} / A_{Nco}) \psi_{ec,N} \psi_{ed,N} \psi_{c,N} \psi_{cp,N} N_b \text{ (Sec. 17.5.1.2 \& Eq. 17.7.3.1b)}$$

$K_{cp}$	$A_{Nc}$ (in <sup>2</sup> )	$A_{Nco}$ (in <sup>2</sup> )	$\psi_{ec,N}$	$\psi_{ed,N}$	$\psi_{c,N}$	$\psi_{cp,N}$	$N_b$ (lb)	$\phi$	$\phi V_{cpg}$ (lb)
2.0	614.25	182.25	1.000	1.000	1.000	1.000	8888	0.70	41941

**11. Results**

**Interaction of Tensile and Shear Forces (Sec. 17.8)**

Tension	Factored Load, $N_{ua}$ (lb)	Design Strength, $\phi N_n$ (lb)	Ratio	Status	
Steel	1467	14303	0.10	Pass	
Concrete breakout	3115	9098	0.34	Pass	
<b>Pullout</b>	<b>1467</b>	<b>3682</b>	<b>0.40</b>	<b>Pass (Governs)</b>	
Shear	Factored Load, $V_{ua}$ (lb)	Design Strength, $\phi V_n$ (lb)	Ratio	Status	
Steel	210	6455	0.03	Pass	
<b>T Concrete breakout y+</b>	<b>840</b>	<b>10239</b>	<b>0.08</b>	<b>Pass (Governs)</b>	
<b>   Concrete breakout x-</b>	<b>420</b>	<b>16120</b>	<b>0.03</b>	<b>Pass (Governs)</b>	
Pryout	840	41941	0.02	Pass	
Interaction check	$N_{ua} / \phi N_n$	$V_{ua} / \phi V_n$	Combined Ratio	Permissible	Status
Sec. 17.8.1	0.40	0.00	39.8%	1.0	Pass

5/8"Ø CS Strong-Bolt 2, hnom:5.125" (130mm) meets the selected design criteria.



Anchor Designer™  
Software  
Version 3.1.2209.3

Company:	AHBL	Date:	9/8/2022
Engineer:	ADM	Page:	6/6
Project:	Korum Ford EV Court		
Address:	2215 North 30th, Suite 300		
Phone:	253.383.2422		
E-mail:	dmceachern@ahbl.com		

## 12. Warnings

- Per designer input, ductility requirements for tension have been determined to be satisfied – designer to verify.
- Per designer input, ductility requirements for shear have been determined to be satisfied – designer to verify.
- Designer must exercise own judgement to determine if this design is suitable.
- Refer to manufacturer's product literature for hole cleaning and installation instructions.

