



City of Puyallup

Engineering Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 10, 2023

Inspection Result: **FAILED**

Permit Number: PRFUP20221635

Property Address: 300 RIVER RD, PUYALLUP, WA 98371;

Contractor: COMCAST - SEFNCO 410 VALLEY AVE #101 NW PUYALLUP, WA 99999

To construct: Comcast proposes to bore and place 1 (2") conduit with 48CT Fiber ~55'

On this day we have inspected your construction for **Engineering Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Per the inspection on 5/22/23 the contractor damaged the gutter on the new curb when removing the asphalt on the grind and overlay. Replace the curb and gutter before final

Corrections:

Sincerely,

Jeff Hill
Engineering Tech IV
Jhill@PuyallupWA.gov
(253) 841-5424