



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Jul 11, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCCP20220770

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152  
Raygan Kettman 1001 SHAW RD E PUYALLUP, WA 98372

**To construct:** The project proposes a new STEM classroom and laboratory building and a new parking lot, net gain of 100 stalls. Improvements include asphalt paving, concrete paving, a new building, utilities services for the new building, and stormwater management. Utility services include domestic water and water main, sewer main and services, natural gas, primary and secondary power, and telecommunications. Modifications to the existing parking lot east of the building and sidewalks adjacent to the building will occur. A belowground detention facility utilizing Stormtech MC-7200 chambers are proposed for stormwater flow control. A bioretention facility will be used upstream of the proposed flow control facility to provide stormwater quality treatment for pollution generating impervious surfaces (PGIS).

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** Tunista air tested the sewer at 4psi for 15min. each.

- SSMH5 to building c/o, 97LF of 8"pvc. (PASSED)
- SSMH5 to SSMH4, 181LF of 8"pvc. (PASSED)
- SSMH3 to SSMH4, 155LF of 8"pvc. (PASSED)
- SSMH3 to SSMH2, 47LF of 8"pvc. (PASSED)
- SSMH2 to SSMH1, 162LF of 8"pvc. (PASSED)

Another crew worked on installing the 3"DI for the water service between the RPBA and the 90deg. bend at the building. They poured thrust blocks as well.

**Corrections:**



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Jason Little  
Engineering Tech IV  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 435-3636