



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 15, 2023

Inspection Result: NOT READY

Permit Number: PRCTI20230304

Property Address: 1102 E MAIN, PUYALLUP, WA 98372;

Contractor: PINNACLE CONSTRUCTION INC PO BOX 426 GLENWOOD, IA 51534

To construct: Interior building remodel. New electrical . New plumbing supply lines .
Two new bathrooms along with air supply and connections to existing
sewer. Relocate hot water heater and provide new exit door. New
insulation ceilings and cosmetic improvements throughout.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. provide header at new exterior door .
2. provide engineering for stud repair at bearing wall as discussed with contractor
3. provide min threshold ht at door to landings interior and exterior as discussed with contractor
4. tenant in back space needs to meet with city to obtain occupancy

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590