

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Jul 18, 2023	Inspection Result:	PARTIAL PASS
Permit Number: Property Address:	PRCTI20230447 2504 E MAIN, PUYALLUP	r, WA 98372;	
Contractor:	POE CONSTRUCTION IN	C. PO BOX 899 AUBUR	N, WA 98071-0899
To construct:	Installation of manufacturing equipment and machines, crane structure, assembly and testing workstations and storage racking within existing warehouse building. Work includes existing slab modifications for new		
	equipment foundations, equipment anchorage, and new roof		
	penetrations for equipment exhaust piping.		

On this day we have inspected your construction for **Gas Test Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ;approved gas pipe test at 60 psi for process oven as noted on sheet p1.1 of approved plans.

2; approved test of nitrogen at 450 psi as noted on sheet p3.0 of approved plans.

Corrections:

Sincerely,

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684

King



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org