



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 19, 2023

Inspection Result: **FAILED**

Permit Number: PRMH20230873

Property Address: 3500 S MERIDIAN, Unit: 235, PUYALLUP, WA 98373;

Contractor: EVERGREEN REFRIGERATION 727 S KENYON SEATTLE, WA 98108

To construct: INSTALLATION (1) A/H UNIT (1) CONDENSING UNIT, DUCTWORK, & GRILLES/DIFFUSERS BATH & BODY WORKS/REMOTE STORAGE UNIT #142.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1) rooftop unit skids, and unit not anchored to roof per approved plan. Install per mechanical engineer, plans or provide revision for alterations.
- 2 1 I complete all bracing of mechanical equipment as per plans.
2 ; provide electrical final prior to mechanical final.
3 ; complete labeling of equipment on roof for space as discussed with contractor.
4 ; seal doghouse on roof at refrigeration line set.

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684