



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Jul 19, 2023

Inspection Result: PASSED

Permit Number: PRCTI20230029

Property Address: 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

Contractor: DOUBLE J ENTERPRISES LLC (DBA JEM CONSTRUCTION 29506 8TH AVENUE S ROY, WA 98580

To construct: Construction of demising walls to create a new rated exit hall with new doors in the exterior wall and start of hall for Units 900-20 (New Level 360) and Unit 930 (Goldfish Swim School).

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. provide city approved plans at time of next inspection
2. complete fire taping
3. complete wall tie ins at tilt up walls on pool side
4. drywall over lap needs to be able to move freely southwall
5. all penetrations thru wall need to be fire caulked
6. [not ready]
- 2 1 ; nobody onsite at time of inspection. (10:15 am no access)
2 ; provide fire final prior to building final.
3 ; complete all rated doors as discussed with Ron on phone.
4 ; provide city approved plans at time of inspection
not ready
- 3 1 ; nobody onsite at time of inspection - no access 8:45 (door locked)

Sincerely,



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

A handwritten signature in black ink that reads "Shannon King". The signature is written in a cursive style with a large initial 'S' and 'K'.

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684