



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFA20230883

FIRE ALARMS

Puyallup, WA

Job Address	Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371 Parcel # 0420212076	ISSUED July 20, 2023
Owner AMB INSTITUTIONAL ALLIANCE FUND III LP 1800 WAZEE ST DENVER, CO 80202		
Applicant Angel Grohall Washington Ave S #91, Washington Ave S #91 Kent, WA 98032 (253) 872-1905 angelg@olsenelectric.net		
Contractor OLSEN ELECTRIC INC 325 WASHINGTON AVE # S KENT, WA 98032 WA L&I #:		
Description of Work Install new fire alarm devices in new office TI, tie into existing system. - PROLOGIS		
Permit Types	Fire Alarms	
Expiration Date: January 16, 2024		
Total ESU's		

Building Components:

Quantity	Units	Description
31	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration
		Total Value of Work: \$0.00

Standard Conditions:

1. • Appointment required for all inspections am/pm is not guaranteed without appointment. Larger systems taking more than 1 hour will require 48-72hr notice prior to scheduling.

- Provide plans and permit on site for inspection.
- Complete labor and industries inspections prior to requesting city inspection.
- If there is an existing annunciator on the exterior of the building it will need to be moved inside the main entrance.

Please contact fire inspector for further information.

- Exterior fire bell required outside fire sprinkler room.
- Above ceiling detection is required.
- Device maps required at the annunciator and fire alarm panel prior to calling in final. The annunciator map will need to be weatherproof.
- Total coverage is required, subject to field inspection. Comply with NFPA 72.
- Fire alarm system shall be placarded per NFPA 72. The UL certificate shall be posted at time of final inspection. The system will need to be UL certified.

- Pre-test shall be conducted with a printout for inspector at time of inspection.
- Labeling of all devices above and below ceiling required.
- RTU'S and smoke dampeners will be required to be tested during inspection.
- The city of Puyallup allows one FACP per building. The panel will need to be large enough to handle multiple tenants if applicable.
- In existing buildings all above ceiling detection is to remain. Do not remove.
- Due to unforeseeable construction design, all device locations to be field verified for compliance.

Schedule your inspection online through the city of puyallup online permit system after requesting appointment from inspector.

Fire Inspections are Monday – Thursday there will be no inspections on Fridays.

David Drake 253-864-4171 ddrake@puyallupwa.gov

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Angel Grohall