

UNDERGROUND PIPE SHOWN FOR REFERENCE ONLY  
SEE CIVIL PLAN SET (BY OTHERS) FOR MORE INFORMATION

- SYMBOLS:**
- SWAY BRACING
  - PIPE HANGER
  - PIPE HANGER W/ BRANCH LINE RESTRAINT
  - FLEXIBLE COUPLING
  - RIGID COUPLING
  - HYDRAULIC NODE
  - GATE VALVE-N.R.S. (GV)
  - ELECTRIC BELL
  - FIRE DEPARTMENT CONNECTION (STANDARD)
  - FIRE DEPARTMENT CONNECTION (SIDEWALK)
  - EXISTING FIRE HYDRANT
  - NEW FIRE HYDRANT
  - POST INDICATOR VALVE (PIV)
  - THRUST BLOCK
  - FLANGED CONNECTION
  - EXISTING SPRINKLER PIPING (SITE PLAN)
  - NEW SPRINKLER PIPING BY OTHERS (SITE PLAN)
  - NEW SPRINKLER PIPING BY SHINN MECH. (SITE PLAN)
  - CENTERLINE OF PIPE ABOVE FINISHED FLOOR
  - FLOOR SECTION DETAIL ARROW POINTS VIEW DIRECTION

**SCOPE OF WORK:**  
SHINN FIRE PROTECTION TO DESIGN AND INSTALL NEW WET AND DRY FIRE SPRINKLER SYSTEMS, WET MANUAL STANDPIPES BASED ON NFPA 14 - 2016. SCOPE OF WORK STARTS AT 12" ABOVE FINISHED FLOOR IN THE RISER ROOM

**UNDERGROUND NOTES: (BY OTHERS)**

- ALL UNDERGROUND TO BE BY OTHERS. CONTRACTOR TO BE STATE LICENSED AND CERTIFIED TO INSTALL UNDERGROUND PIPING PER WAC 212-80.
- THE DESIGN AND INSTALLATION OF THE FIRE PROTECTION UNDERGROUND SHALL BE PERFORMED PER SECTION 212.08.18 OF THE "WASHINGTON ADMINISTRATIVE CODE" (WAC)
- UNDERGROUND PIPING TO BE PROPERLY THRUST BLOCKED PER NFPA 24 WITH A MINIMUM OF 3'-0" BELOW FROST LINE.
- SHINN FIRE PROTECTION'S SCOPE OF WORK STARTS AT 12" ABOVE FINISHED FLOOR IN THE RISER ROOM

**SPECIAL FIELD INSTRUCTIONS:**

- INSTALL TEMPORARY PROTECTION (RED CAP) AND OR PLASTIC BAGS ON ALL SPRINKLER HEADS AS REQUIRED TO AVOID COLLISION BY OTHER TRADES AND PAINT OVERSPRAY. ALL TEMPORARY PROTECTION MEASURES TO BE REMOVED PRIOR TO SYSTEM BEING PLACED IN SERVICE.

**GENERAL NOTES:**

- FIRE SPRINKLER SYSTEMS ARE TO BE DESIGNED, INSTALLED & TESTED IN ACCORDANCE WITH NFPA 14 & 25, 2016 EDITION, AS AMENDED BY THE STATE FIRE MARSHALL & THE CITY OF PUYALLUP FIRE DEPT.
- ALL MATERIALS AND EQUIPMENT TO BE INSTALLED SHALL BE UL LISTED OR FM APPROVED.
- IT IS THE OWNER'S RESPONSIBILITY TO ENSURE THAT THE STRUCTURE CAN ADEQUATELY SUPPORT ALL FIRE SPRINKLER PIPE AND SEISMIC LOADS.
- OWNER IS RESPONSIBLE FOR MAINTAINING TEMPERATURES ABOVE 40°F TO PROTECT THE WET FIRE SPRINKLER SYSTEM FROM FREEZING. FIRE SPRINKLER SYSTEM HEATED BY BUILDING CENTRAL HEATING SYSTEM
- ALL WIRING OF FIRE PROTECTION SYSTEM COMPONENTS TO BE DONE BY OTHERS. ALL WIRING AND MATERIAL SHALL BE LISTED IN ACCORDANCE WITH NFPA 70 (NEC) LATEST EDITION ADOPTED.
- CENTRAL STATION MONITORING EQUIPMENT, WIRING AND SERVICES TO BE DONE BY OTHERS.
- HANGERS TO BE PER NFPA 13 AS SHOWN ON THE DRAWINGS
- NOTIFICATIONS: CENTRAL ALARM SYSTEM (BY OTHERS)
- ALL NEW SYSTEMS SHALL BE HYDROSTATICALLY TESTED AT 200PSI OR 50 PSI OVER SYSTEM PRESSURE, WHICHEVER IS GREATER FOR 2 HRS.
- ALL ORDINARY TEMPERATURE SPRINKLERS TO BE LOCATED AT LEAST 12" AWAY FROM EDGE OF DIFFUSER AND 6" AWAY FROM LIGHTS (0-250W)
- ALL ALARM OVERS EXCEEDING 24" TO BE PROVIDED WITH A HANGER
- NOTIFICATION IS PROVIDED BY INTERIOR/EXTERIOR HORN & STROBE. ALL SYSTEMS TO BE MONITORED 24 HRS A DAYS BY A CENTRAL STATION. (BY OTHERS)
- EXTERIOR HORN & STROBE TO BE PROVIDED & LOCATED ON SIDE OF BUILDING CLOSEST TO REMOTE FDC (BY OTHERS)
- ACT GRID CEILINGS - ALL SPRINKLER HEADS TO BE CENTER OF 2X2 TILES.

**DRAWING INDEX:**

- FP 0.10 SITE PLAN AND NOTES
- FP 1.00 STAND PIPE AND CROSS MAIN DETAIL
- FP 2.00 FIRE SPRINKLER PLAN - FLOOR 00 & DETAILS
- FP 2.10 FIRE SPRINKLER PLAN - FLOOR 01
- FP 2.20 FIRE SPRINKLER PLAN - FLOOR 02
- FP 2.30 FIRE SPRINKLER PLAN - FLOOR 03
- FP 2.40 FIRE SPRINKLER PLAN - ROOF PLAN

**WATER SUPPLY:**


SOURCE: PUYALLUP UTILITIES COMPUTER MODEL  
 STATIC PSI: 64 PSI  
 RESIDUAL: 20 PSI  
 FLOW: 1950 GPM  
 LOCATION: 640 RAILROAD AVE  
 DATE: 02-11-2022  
 HYDRANT LOCATION: HYDRANT #SE682

**PROJECT HEAD COUNTS: TOTAL FOR ALL PAGES**


| SYM | MFG      | TYPE     | SIN #  | K-FACTOR | THR  | TEMP  | FINISH | QTY   |     |
|-----|----------|----------|--------|----------|------|-------|--------|-------|-----|
| ○   | RELIABLE | UPRIGHT  | F1FR56 | 5.6      | 1/2" | 155°F | BRONZE | 319   |     |
| ●   | RELIABLE | PENDENT  | F1FR80 | 8.0      | 3/4" | 155°F | CHROME | 163   |     |
| ○   | RELIABLE | PENDENT  | F1FR56 | 5.6      | 1/2" | 155°F | CHROME | 197   |     |
| ●   | RELIABLE | PENDENT  | F1FR56 | 5.6      | 1/2" | 155°F | CHROME | 9     |     |
| ○   | RELIABLE | PENDENT  | F1FR28 | 2.8      | 1/2" | 200°F | CHROME | 4     |     |
| ▷   | RELIABLE | SIDEWALL | F1FR56 | 5.6      | 1/2" | 155°F | BRONZE | 10    |     |
|     |          |          |        |          |      |       |        | TOTAL | 702 |

- DESIGN NOTES:**
- BUILDING STRUCTURE IS NON-COMBUSTIBLE CONCRETE AND STEEL CONSTRUCTION.
  - SPRINKLER DEFLECTOR AND LOCATIONS SHALL BE DESIGNED IN ACCORDANCE WITH NFPA #13 - 2016.
  - ALL SEISMIC BRACING AND HANGER ASSEMBLIES TO BE INSTALLED IN ACCORDANCE TO NFPA #13 - 2016. PER NFPA 13 SECTION 9.3.6.5 BRANCHLINES WITH HANGER RODS LESS THAN 6" SHALL NOT REQUIRE BRANCH LINE END OF LINE RESTRAINT AND LATERAL BRACES.
  - THREADED PIPE TO BE SCH-40 ANSI, ASTM A53, OR A135, BLACK WET SYSTEM.
    - ROLL GROOVED PIPING: 1.5" TO 4" - SCH 10, ANSI/ASTM A795, BLACK WET SYSTEM
    - ROLL GROOVED PIPING: 6" & 8" - SCH 10, ASTM A-135, BLACK WET SYSTEM
  - THREADED PIPE TO BE SCH-40 ANSI, ASTM A53, OR A135, GALV. DRY SYSTEM.
    - ROLL GROOVED PIPING: 1.5" TO 4" - SCH 10, ANSI/ASTM A795, GALV DRY SYSTEM
    - ROLL GROOVED PIPING: 6" & 8" - SCH 10, ASTM A-135, GALV DRY SYSTEM
  - THREADED FITTINGS TO BE DUCTILE/MALLEABLE IRON, 125#
    - GROOVED FITTINGS - VICTAULIC FIRELOCK OR EQUAL
    - WELDED OUTLETS - BY MERITS OR EQUAL
  - WORKING PRESSURE:
    - ALL PIPE FITTINGS TO BE LISTED FOR PRESSURES OVER 200 PSI
    - SCH. 10 & 40 PIPE RATED FOR 300 PSI
    - FIRELOCK FITTINGS & COUPLINGS ARE RATED FOR 365 PSI
  - A REMOTE F.D.C. IS PROVIDED AND INSTALLED BY OTHERS
  - LIGHT HAZARD OCCUPANCY (0.1/1500) - CLASSROOMS, OFFICES, RESTROOMS, CORRIDORS/HALLWAYS, CONFERENCE ROOMS, LOUNGE & ATTIC SPACE.
  - OH GR I (0.15/1500) MECHANICAL ROOMS
  - OH GR II (0.2/1500) - LAB SPACES
  - A REDUCTION IN THE REMOTE AREA IS USED WHERE Q.R. SPRINKLER HEADS ARE INSTALLED.

- DESIGN CRITERIA:**  
PER NFPA 13 (2016), AND CITY OF PUYALLUP FIRE MARSHAL.
- LEVEL 0 - BOILER ROOM  
ORDINARY GROUP I HAZARD  
DESIGN DENSITY: 0.15 GPM / 1500 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 40% REDUCTION, 1500 SF \* 40% = 600 SF  
1500 SF - 600 SF = 900 SF
  - LEVEL 1 - FAB LAB  
ORDINARY GROUP II HAZARD  
DESIGN DENSITY: 0.20 GPM / 1500 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 33% REDUCTION, 1500 SF \* 33% = 495 SF  
1500 SF - 495 SF = 1005 SF
  - LEVEL 1 - CLOSELY SPACED HEADS  
LIGHT HAZARD  
DESIGN DENSITY: 0.10 GPM / 7 HEADS  
WET SYSTEM
  - LEVEL 1 - CLASSROOM 101 / 102  
LIGHT HAZARD  
DESIGN DENSITY: 0.10 GPM / 1555 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 33% REDUCTION, 1500 SF \* 33% = 495 SF  
1500 SF - 495 SF = 1005 SF
  - LEVEL 2 - EAST ENTRY - HIGH BAY AREA  
LIGHT HAZARD  
DESIGN DENSITY: 0.10 GPM / 1335 SF  
WET SYSTEM
  - LEVEL 2 - GENERAL BIOLOGY LAB  
ORDINARY GROUP II HAZARD  
DESIGN DENSITY: 0.20 GPM / 1005 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 40% REDUCTION, 1500 SF \* 40% = 600 SF  
1500 SF - 600 SF = 900 SF
  - LEVEL 2 - CLASSROOM 201 / 202  
LIGHT HAZARD  
DESIGN DENSITY: 0.10 GPM / 1555 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 33% REDUCTION, 1500 SF \* 33% = 495 SF  
1500 SF - 495 SF = 1005 SF
  - LEVEL 2 - EAST DOOR OVER HANG  
LIGHT HAZARD  
DESIGN DENSITY: 0.10 GPM / FULL SYSTEM  
WET SYSTEM
  - LEVEL 3 - ORGANIC CHEMISTRY LAB  
ORDINARY GROUP II HAZARD  
DESIGN DENSITY: 0.20 GPM / 976 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 40% REDUCTION, 1500 SF \* 40% = 600 SF  
1500 SF - 600 SF = 900 SF
  - LEVEL 3 - EARTH SCIENCE LAB B  
ORDINARY GROUP II HAZARD  
DESIGN DENSITY: 0.20 GPM / 976 SF  
WET SYSTEM, QR HEADS  
DESIGN AREA REDUCTION PER NFPA 13 (2016) SECTION 11.2.3.2.3.1  
- 3" 1/2 + 55 = 40% REDUCTION, 1500 SF \* 40% = 600 SF  
1500 SF - 600 SF = 900 SF
  - LEVEL 4 - MECHANICAL PENTHOUSE  
ORDINARY GROUP I HAZARD  
DESIGN DENSITY: 0.15 GPM / 418 SF  
WET SYSTEM



**1 ) FIRE SPRINKLER SECTION VIEW**  
SCALE 1/8"=1'-0"



**2 ) FIRE SPRINKLER SECTION VIEW**  
SCALE 1/8"=1'-0"

**VICINITY MAP:**

**SHINN**  
FIRE PROTECTION

18802 80th Avenue S  
Kent, WA 98032

Phone: (425) 203-9800  
Fax: (425) 203-9801

WA CL# SHINNMI060QP  
www.shinnmechanical.com

**PROJECT:**  
PIERCE COLLEGE  
PUYALLUP NEW  
STEM BUILDING

1601 39th AVE SE  
Puyallup, WA 98374

**CONTRACTOR:**  
**Absher Construction**  
P.O. Box 280  
Puyallup, WA 98371  
PRECON DIRECTOR Blaine Wolfe  
Phone: (253) 845-9544

**KEY PLAN:**

**REVISIONS:**  
7-11-23 FM Review-Notes added

**AHJ:**  
CITY OF PUYALLUP

**NICET STAMP:**

FPET NICET #106245 LEVEL IV ASME  
WASHINGTON STATE  
CERTIFICATE OF COMPETENCY  
FIRE PROTECTION SPRINKLER SYSTEMS

Hussain A. A. Huballa  
8321-1119-C Level 3  
Shinn Mechanical, Inc.  
SHINNMI060QP

Signature:

05/16/2023

**DATE:** 05/15/2023  
**JOB NUMBER:** 22-3688  
**DESIGNER:** Ben Bernard  
**PM:**

**SITE PLAN AND NOTES**

**FP-0.0**



18802 80th Avenue S  
Kent, WA 98032  
Phone: (425) 203-9800  
Fax: (425) 203-9801  
WA CL# SHINNMI060QP  
www.shinnmechanical.com

PROJECT:  
**PIERCE COLLEGE  
PUYALLUP NEW  
STEM BUILDING**

1601 39th AVE SE  
Puyallup, WA 98374


CONTRACTOR:  
**Absher  
Construction**

P.O. Box 280  
Puyallup, WA 98371  
PRECON DIRECTOR Blaine Wolfe  
Phone: (253) 845-9544

KEY PLAN:

REVISIONS:  
▲ 7-11-23 FM Review-Notes added

AHJ:  
CITY OF PUYALLUP



DATE: 05/16/2023  
JOB NUMBER: 22-3688  
DESIGNER: Ben Bernard  
PM:

3/4 VIEW STAND PIPE  
PLAN AND DETAILS



**FP-1.0**

STANDPIPE HOSE FLOW CALCULATED WITH A MINIMUM FLOW OF 154 PSI @ 750 GPM FROM YARD MOUNTED FDC IN FRONT OF BUILDINGS SOUTH ENTRANCE (NODE #4). CITY WATER SUPPLY TO BUILDING DOES NOT EXCEED 175 PSI NOR DOES STANDPIPE REQUIREMENTS, THUS ALL HOSE VALVES ARE TO BE INSTALLED WITH-OUT PRESSURE REDUCING DEVICES.


| Hydraulic Information          |               |
|--------------------------------|---------------|
| Remote Area ROOF TOP HOSE FLOW |               |
| TOTAL WATER REQUIRED           | 750.00        |
| TOTAL PRESSURE REQUIRED        | 152.781       |
| SAFETY MARGIN (psi)            | +1.219 (0.8%) |

PER NFPA 14, 2016 EDITION


A 7.3.2 HOSE CONNECTIONS ARE NOW SPECIFIED TO BE LOCATED AT THE MAIN FLOOR LANDING IN EXIT STAIRWAYS. PARAGRAPH 7.3.2.1 PERMITS HOSE CONNECTIONS TO BE LOCATED AT INTERMEDIATE LANDINGS WHERE LOCAL FIRE-FIGHTING TACTICS REQUIRE THIS LOCATION. ONLY ONE STANDPIPE IS NECESSARY TO SERVE THE ROOF REGARDLESS OF THE TRAVEL DISTANCES IN 7.3.2.2. IT IS NOT THE INTENT TO EXTEND EACH STANDPIPE TO THE ROOF LEVEL.




FIRE SPRINKLER WET MANUAL STANDPIPE AND RISER LOCATIONS  
SCALE 1/8"=1'-0"



SB-1  
I-BEAM = Fig. AF772,PERP / Fig. AF700 / AF730




SB-2  
I-BEAM = Fig. AF772,PARA / Fig. AF700 / AF730




| AGF ITEM ID | PIPE Ø | A (mm)       | B (mm)      |
|-------------|--------|--------------|-------------|
| 7930ECA-20  | 2"     | 4-1/8" (105) | 4-7/8 (124) |
| 7930ECA-25  | 2-1/2" | 4-3/8" (113) | 4-7/8 (124) |
| 7930ECA-30  | 3"     | 4-3/8" (113) | 4-7/8 (124) |
| 7930ECA-40  | 4"     | 7-1/8" (181) | 4-7/8 (124) |
| 7930ECA-60  | 6"     | 8-1/8" (207) | 4-7/8 (124) |
| 7930ECA-80  | 8"     | 9" (230)     | 4-3/4 (120) |

AGF MANUFACTURING INC.  
PURGENT END CAP ASSEMBLY




MECH ROOM SPRINKLER RISER  
FLOOR 0 - MECH SPACE

- NOTES:
- 6" UNDERGROUND SUPPLY (BY OTHERS)
  - 2" ANNULAR DISTANCE CLEAR AROUND PIPE WITH PIPE CLAMP FLOOR PENETRATION (BY OTHERS)
  - 3" RELIABLE MODEL BFG-300 SUPERVISED BUTTERFLY VALVE GROOVED
  - 3" RELIABLE MODEL G SWING CHECK VALVE, GxG
  - 3" RELIABLE MODEL CR COMMERCIAL RISER W/ TEST AND DRAIN VALVE
  - 3" x 2 1/2" REDUCING COUPLING
  - 6" FLEXIBLE COUPLING



HANGER - 21S  
EXPRESS SAMMY




LEVEL 1 - FS RISER RM.

- NOTES:
- 6" UNDERGROUND SUPPLY (BY OTHERS)
  - 2" ANNULAR DISTANCE CLEAR AROUND PIPE WITH PIPE CLAMP FLOOR PENETRATION (BY OTHERS)
  - GxG TEE
  - 6" RELIABLE MODEL BFG-300 SUPERVISED BUTTERFLY VALVE GROOVED
  - 6" RELIABLE MODEL G SWING CHECK VALVE, GxG
  - 6" RELIABLE MODEL CR COMMERCIAL RISER W/ TEST AND DRAIN VALVE
  - 6" FLEXIBLE COUPLING
  - 6" BLACK STEEL PIPE TO MANUAL WET STANDPIPE
  - 6" BLACK STEEL PIPE TO WET SYSTEM ON FLOOR 0 & 1
  - 6" BLACK STEEL PIPE TO WET SYSTEM ON FLOOR 2
  - 6" BLACK STEEL PIPE TO WET SYSTEM ON FLOOR 3
  - 1" BALL VALVE W/ SQUARE HEAD PLUG
  - 2" SCH-40 BLACK PIPE MAIN DRAIN \*
  - 2" SCH-40 PIPE STAND W/ 4 CONC. ANCHORS IN FLOOR
  - SPRINKLER HEAD CABINET
  - BACKING BOX AND 10" ELECTRIC BELL (WIRED BY OTHERS)\*
  - DRAIN PIPING SHALL BE ROUTED TO FLOOR DRAIN WITH AIR GAP
  - HOSE VALVE FOR FORWARD FLOW TESTING OF BACK FLOW DEVICE\*\*
  - 3" RELIABLE MODEL BFG-300 SUPERVISED BUTTERFLY VALVE GROOVED
  - 3" RELIABLE MODEL G SWING CHECK VALVE, GxG
  - 3" RELIABLE MODEL CR COMMERCIAL RISER W/ TEST AND DRAIN VALVE
  - 3" FLEXIBLE COUPLING
- \*BELL SHALL BE MOUNTED TO EXTERIOR OF BUILDING.  
\*\* HIGHEST FLOWING CALCULATION FLOWS @ 758GPM,  
3 HOSE VALVES ARE REQUIRED PER NFPA 13 16.14.5.1.1.

Hydraulic Information

| Remote Area 1                  |   |
|--------------------------------|---|
| OCCUPANCY CLASSIFICATION       | Ordinary Group 1  |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.15 for 1500ft <sup>2</sup> (Actual 922ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 10'-0" Ceiling (40.0%) 900ft <sup>2</sup>                 |
| TOTAL HOSE STREAMS             | 250.00  |
| TOTAL HEADS FLOWING            | 19  |
| K-FACTOR                       | 5.6   |
| TOTAL WATER REQUIRED           | 563.64  |
| TOTAL PRESSURE REQUIRED        | 43.567  |
| BASE OF RISER (gpm)            | 563.64  |
| BASE OF RISER (psi)            | 43.567  |
| SAFETY MARGIN (psi)            | +16.016 (26.9%)   |



FIRE SPRINKLER PLAN - LEVEL 0

SCALE 1/8"=1'-0"

Sprinkler Legend

| Symbol | Manufacturer | Model  | K-Factor | Type     | Size | Response | Finish | Temperature | Quantity   |
|--------|--------------|--------|----------|----------|------|----------|--------|-------------|------------|
| ○      | RELIABLE     | FIFR56 | 5.6      | Upright  | 1/2" | Quick    | BRASS  | 155°F       | 19         |
| ●      | RELIABLE     | FIFR56 | 5.6      | Pendent  | 1/2" | Quick    | Chrome | 155°F       | 5          |
| △      | RELIABLE     | FIFR56 | 5.6      | Sidewall | 1/2" | Quick    | Chrome | 155°F       | 1          |
|        |              |        |          |          |      |          |        |             | Total = 25 |

**SHINN**  
FIRE PROTECTION

18802 80th Avenue S  
Kent, WA 98032

Phone: (425) 203-9800  
Fax: (425) 203-9801

WA CL# SHINNMI060QP  
www.shinnmechanical.com

PROJECT:  
**PIERCE COLLEGE  
PUYALLUP NEW  
STEM BUILDING**

1601 39th AVE SE  
Puyallup, WA 98374

CONTRACTOR:  
**Absher  
Construction**

P.O. Box 280  
Puyallup, WA 98371  
PRECON DIRECTOR Blaine Wolfe  
Phone: (253) 845-9544

KEY PLAN:

REVISIONS:  
7-11-23 FM Review-Notes added


AHJ:  
CITY OF PUYALLUP

NICET STAMP:  
FPET NICET #106245 LEVEL IV (ASME)  
WASHINGTON STATE  
CERTIFICATE OF COMPETENCY  
FIRE PROTECTION SPRINKLER SYSTEMS  
Hussein A. A. Huballa  
8321-1119-C Level 3  
Shinn Mechanical, Inc.  
SHINNMI060QP  
05/16/2023  
Signature: [Signature]

DATE: 05/16/2023  
JOB NUMBER: 22-3688  
DESIGNER: Ben Bernard  
PM:

ZERO FLOOR FIRE  
SPRINKLER PLANS

FP-2.0



**Hydraulic Information**

Remote Area 2

|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Ordinary Group II  |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.20 for 1500ft <sup>2</sup> (Actual 1027ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 14'-8 Ceiling (33.0%) 1005ft <sup>2</sup>                  |
| TOTAL HOSE STREAMS             | 250.00   |
| DRY CAPACITY                   | 0.00gal  |
| TOTAL HEADS FLOWING            | 15   |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 637.25   |
| TOTAL PRESSURE REQUIRED        | 47.625   |
| BASE OF RISER (gpm)            | 637.25   |
| BASE OF RISER (psi)            | 47.625   |
| SAFETY MARGIN (psi)            | +10.818 (18.5%)  |

**Hydraulic Information**

Remote Area 3

|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Light Hazard   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.10 for 1500ft <sup>2</sup> (Actual 1099ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 14'-8 Ceiling (33.0%) 1005ft <sup>2</sup>                  |
| TOTAL HOSE STREAMS             | 100.00   |
| TOTAL HEADS FLOWING            | 22   |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 508.62   |
| TOTAL PRESSURE REQUIRED        | 48.425   |
| BASE OF RISER (gpm)            | 508.62   |
| BASE OF RISER (psi)            | 48.425   |
| SAFETY MARGIN (psi)            | +11.913 (19.7%)  |

**Hydraulic Information**


Remote Area 4

|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Light Hazard   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.10 for 1500ft <sup>2</sup> (Actual 1045ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 14'-8 Ceiling (33.0%) 1005ft <sup>2</sup>                  |
| TOTAL HOSE STREAMS             | 100.00   |
| DRY CAPACITY                   | 0.00gal  |
| TOTAL HEADS FLOWING            | 12   |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 290.92   |
| TOTAL PRESSURE REQUIRED        | 37.798   |
| BASE OF RISER (gpm)            | 290.92   |
| BASE OF RISER (psi)            | 37.798   |
| SAFETY MARGIN (psi)            | +24.899 (39.7%)  |

**Hydraulic Information (HIGH BAY AREA)**

Remote Area 5


|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Light Hazard   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.10 for 1500ft <sup>2</sup> (Actual 1335ft <sup>2</sup> ) |
| TOTAL HOSE STREAMS             | 100.00   |
| TOTAL HEADS FLOWING            | 14   |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 314.93   |
| TOTAL PRESSURE REQUIRED        | 29.635   |
| BASE OF RISER (gpm)            | 314.93   |
| BASE OF RISER (psi)            | 29.635   |
| SAFETY MARGIN (psi)            | +32.857 (52.6%)  |



(1) Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5. Fire Sprinklers located in sump of elevator only

**Sprinkler Legend**

| Symbol | Manufacturer | Model  | K-Factor | Type     | Size | Response | Finish | Temperature | Quantity    |
|--------|--------------|--------|----------|----------|------|----------|--------|-------------|-------------|
| ○      | RELIABLE     | FIFR56 | 5.6      | Upright  | 1/2  | Quick    | Brass  | 155°F       | 174         |
| ◻      | RELIABLE     | FIFR56 | 5.6      | Sidewall | 1/2  | Quick    | Chrome | 155°F       | 3           |
| ●      | RELIABLE     | FIFR56 | 5.6      | Pendent  | 1/2  | Quick    | Chrome | 155°F       | 100         |
|        |              |        |          |          |      |          |        |             | Total = 277 |



**Hydraulic Information**  
Remote Area 6

|                                |   |
|--------------------------------|---|
| OCCUPANCY CLASSIFICATION       | Ordinary Group II   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.20 for 1500ft <sup>2</sup> (Actual 960ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 10'-0" Ceiling (40.0%) 900ft <sup>2</sup>                 |
| TOTAL HOSE STREAMS             | 250.00  |
| TOTAL HEADS FLOWING            | 9   |
| K-FACTOR                       | 8   |
| TOTAL WATER REQUIRED           | 501.26  |
| TOTAL PRESSURE REQUIRED        | 45.628  |
| BASE OF RISER (gpm)            | 501.26  |
| BASE OF RISER (psi)            | 45.628  |
| SAFETY MARGIN (psi)            | +14.807 (24.5%)   |

**Hydraulic Information**  
Remote Area 7

|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Light Hazard   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.10 for 1500ft <sup>2</sup> (Actual 1032ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 14'-8" Ceiling (33.0%) 1005ft <sup>2</sup>                 |
| TOTAL HOSE STREAMS             | 100.00   |
| DRY CAPACITY                   | 0.00gal  |
| TOTAL HEADS FLOWING            | 10   |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 310.62   |
| TOTAL PRESSURE REQUIRED        | 51.897   |
| BASE OF RISER (gpm)            | 310.62   |
| BASE OF RISER (psi)            | 51.897   |
| SAFETY MARGIN (psi)            | +10.632 (17.0%)  |

**Hydraulic Information**  
Remote Area 8

|                                |  |
|--------------------------------|--|
| OCCUPANCY CLASSIFICATION       | Light Hazard   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.10 for 1500ft <sup>2</sup> (Actual 1091ft <sup>2</sup> ) |
| TOTAL HOSE STREAMS             | 100.00   |
| DRY CAPACITY                   | 0.00gal  |
| TOTAL HEADS FLOWING            | 8  |
| K-FACTOR                       | 5.6  |
| TOTAL WATER REQUIRED           | 222.56   |
| TOTAL PRESSURE REQUIRED        | 36.530   |
| BASE OF RISER (gpm)            | 222.56   |
| BASE OF RISER (psi)            | 36.530   |
| SAFETY MARGIN (psi)            | +26.676 (42.2%)  |

SPECIAL NOTE:  
ENTRY WAY OVERHANG - NON-COMBUSTIBLE CONSTRUCTION WITH INSULATION AT THE CEILING LEVEL, OCCUPIED FLOOR ABOVE, AND IT IS WITHIN THE BUILDING ENVELOPE, HENCE A WET SYSTEM WITH DRY SSP ARE PROVIDED.

(1) Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5, Fire Sprinklers located in sump of elevator only.  
(2) Fire Sprinklers omitted from Vertical, concealed, non-combustible shaft areas that comply with NFPA 13 #8.15.1.2

**Sprinkler Legend**

| Symbol | Manufacturer | Model  | K-Factor | Type        | Size | Response | Finish | Temperature | Quantity    |
|--------|--------------|--------|----------|-------------|------|----------|--------|-------------|-------------|
| ●      | RELIABLE     | FIFR56 | 5.6      | Upright     | 1/2" | Quick    | Brass  | 200°F       | 81          |
| ●      | RELIABLE     | F3QR56 | 5.6      | Dry Pendent | 1"   | Quick    | Chrome | 155°F       | 9           |
| ●      | RELIABLE     | FIFR80 | 8        | Pendent     | 3/4" | Quick    | Chrome | 155°F       | 67          |
| ●      | RELIABLE     | FIFR56 | 5.6      | Pendent     | 1/2" | Quick    | Chrome | 155°F       | 57          |
|        |              |        |          |             |      |          |        |             | Total = 214 |

**FIRE SPRINKLER PLAN - SECOND FLOOR**  
SCALE 1/8"=1'-0"

**Hydraulic Information**  
Remote Area 9

|                                |   |
|--------------------------------|---|
| OCCUPANCY CLASSIFICATION       | Ordinary Group II   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.20 for 1500ft <sup>2</sup> (Actual 969ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 10'-0 Ceiling (40.0%) 900ft <sup>2</sup>                  |
| TOTAL HOSE STREAMS             | 250.00  |
| TOTAL HEADS FLOWING            | 10  |
| K-FACTOR                       | 8   |
| TOTAL WATER REQUIRED           | 515.36  |
| TOTAL PRESSURE REQUIRED        | 44.470  |
| BASE OF RISER (gpm)            | 515.36  |
| BASE OF RISER (psi)            | 44.470  |
| SAFETY MARGIN (psi)            | +15.778 (26.2%)   |

Ordinary Group II-0.20gpm/ft<sup>2</sup> for 986ft<sup>2</sup>


**Hydraulic Information**  
Remote Area 10

|                                |   |
|--------------------------------|---|
| OCCUPANCY CLASSIFICATION       | Ordinary Group II   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.20 for 1500ft <sup>2</sup> (Actual 986ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 10'-0 Ceiling (40.0%) 900ft <sup>2</sup>                  |
| TOTAL HOSE STREAMS             | 250.00  |
| DRY CAPACITY                   | 0.00gal   |
| TOTAL HEADS FLOWING            | 10  |
| K-FACTOR                       | 8   |
| TOTAL WATER REQUIRED           | 515.76  |
| TOTAL PRESSURE REQUIRED        | 47.184  |
| BASE OF RISER (gpm)            | 515.76  |
| BASE OF RISER (psi)            | 47.184  |
| SAFETY MARGIN (psi)            | +13.058 (21.7%)   |


**Sprinkler Legend**

| Symbol | Manufacturer | Model  | K-Factor | Type     | Size | Response | Finish | Temperature | Quantity    |
|--------|--------------|--------|----------|----------|------|----------|--------|-------------|-------------|
| ▶      | RELIABLE     | F1FR56 | 5.6      | Sidewall | 1/2" | Quick    | Chrome | 155°F       | 6           |
| ●      | RELIABLE     | F1FR56 | 5.6      | Pendent  | 1/2" | Quick    | Chrome | 155°F       | 35          |
| ○      | RELIABLE     | F1FR56 | 5.6      | Upright  | 1/2" | Quick    | BRASS  | 155°F       | 45          |
| ●      | RELIABLE     | F1FR80 | 8        | Pendent  | 3/4" | Quick    | Chrome | 155°F       | 96          |
|        |              |        |          |          |      |          |        |             | Total = 182 |

(1) Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5, Fire Sprinklers located in sump of elevator only.  
(2) Fire Sprinklers omitted from Vertical, concealed, non-combustible shaft areas that comply with NFPA 13 #8.15.1.2




**FIRE SPRINKLER PLAN - THIRD FLOOR**  
SCALE 1/8"=1'-0"



| Hydraulic Information          |  |
|--------------------------------|--|
| Remote Area 11                 |  |
| OCCUPANCY CLASSIFICATION       | Ordinary Group I   |
| DENSITY (gpm/ft <sup>2</sup> ) | 0.15 for 418ft <sup>2</sup> (Actual 418ft <sup>2</sup> ) |
| QUICK RESPONSE REDUCTION       | 10'-0" Ceiling (40.0%) 251ft <sup>2</sup>                |
| TOTAL HOSE STREAMS             | 250.00   |
| TOTAL HEADS FLOWING            | 4  |
| K-FACTOR                       | 2.8  |
| TOTAL WATER REQUIRED           | 279.78   |
| TOTAL PRESSURE REQUIRED        | 44.009   |
| BASE OF RISER (gpm)            | 279.78   |
| BASE OF RISER (psi)            | 44.009   |
| SAFETY MARGIN (psi)            | +18.779 (29.9%)  |

PER NFPA 14, 2016 EDITION  
A.7.3.2 HOSE CONNECTIONS ARE NOW SPECIFIED TO BE LOCATED AT THE MAIN FLOOR LANDINGS IN EXIT STAIRWAYS. PARAGRAPH 7.3.2.1 PERMITS HOSE CONNECTIONS TO BE LOCATED AT INTERMEDIATE LANDINGS WHERE LOCAL FIRE-FIGHTING TACTICS REQUIRE THIS LOCATION. ONLY ONE STANDPIPE IS NECESSARY TO SERVE THE ROOF REGARDLESS OF THE TRAVEL DISTANCES IN 7.3.2.2; IT IS NOT THE INTENT TO EXTEND EACH STANDPIPE TO THE ROOF LEVEL.



FIRE SPRINKLER PLAN - THIRD FLOOR  
SCALE 1/8" = 1'-0"

| Sprinkler Legend |              |        |          |         |      |          |        |             |           |
|------------------|--------------|--------|----------|---------|------|----------|--------|-------------|-----------|
| Symbol           | Manufacturer | Model  | K-Factor | Type    | Size | Response | Finish | Temperature | Quantity  |
|                  | RELIABLE     | F1FR28 | 2.8      | Pendent | 1/2" | Quick    | Chrome | 155°F       | 4         |
|                  |              |        |          |         |      |          |        |             | Total = 4 |