ROOF WALKWAY UPGRADE MultiCare Good Samaritan Hospital



City of Puyallup Development & Permitting Services ISSUED PERMIT	
Building	Planning
Engineering	Public Works
Fire OF W	Traffic

Access to the equipment or appliances cannot require climbing over obstructions greater than 30 inches over the duct. Fire walls that extend up from the roof surface more than 30 inches would also require permanent steps or ladders.

Permanent ladders shall be constructed in accordance with Section 306.5 of the International Mechanical



OSHA REQUIREMENTS AS THESE STAIRS PROVIDE ACCESS TO AN UNNOCCUPIED ROOF, INSTALLER TO USE MEASURED FIELD VALUES TO DETERMINE RISER HEIGHTS TAKING INTO ACCOUNT MAXIMUMS AND MINIMUMS AND AVOIDING OVERHEAD OBSTRUCTIONS AS NECCESSARY



WALKWAY-ENLARGED







ORIENTATION



ROJECT NO.:



SO