



July 11, 2023

Re: Pierce College STEM Bldg. - Puyallup
22-3698 - Pierce College STEM Bldg. – Comments answer for first review cycle

To: David Drake
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Attn: David (DDrake@PuyallupWA.gov)

Review Letter for Review no.1 from City of Puyallup

Below is a list of all areas we have omitted fire sprinklers from the STEM Building and a short reason or code compliance that we are meeting to achieve or maintain proper fire sprinkler coverage.

FP-2.1 - Floor 1

- Elevator E101 is shown excluded from coverage, Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5, Fire Sprinklers located in sump of elevator only.

FP-2.2 - Floor 2

- Southern overhang omitted, this is a non-combustible overhang and complies with NFPA 13 #8.15.7
- Fire Sprinklers omitted from Vertical, concealed, non-combustible shaft areas that comply with NFPA 13 #8.15.1.2
- Elevator E201 is shown excluded from coverage, Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5, Fire Sprinklers located in sump of elevator only.

FP-2.3 - Floor 3

- Fire Sprinklers omitted from Vertical, concealed, non-combustible shaft areas that comply with NFPA 13 #8.15.1.2
- Elevator shaft and elevator mechanical room omitted by complying with NFPA 13 #8.15.5, Fire Sprinklers located in sump of elevator only.

If you have any questions associated with this, please feel free to call me.

Sincerely,

Ben Bernard

Designer /Project Manager

Benb@shinnmech.com

206-9Z41-9840 = CELL

425-204-394- DESK