

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Aug 02, 2023	Inspection Result:	NOT READY
Permit Number: Property Address:	B-20-0180 3601 9TH ST SW, PUY	'ALLUP, WA 98373;	
Contractor:		TALITY DEV LLC 4520 36	5TH AVE S FARGO, ND ND 58104 (701) 850-9953
To construct:	0	0	TEL *FEE DEFERRAL-SWR*
	REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD PERIMETER DRAINTILE		

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1.complete rebar at elevator pit per city approved plans
 - 2. complete rebar at steps in footings per city approved plans
 - 3. provide special inspection approval with revised plans referenced at time of next inspection
 - 4. not ready
- 2 1. complete rebar that is missing at step per city approved plans
 - provide engineer of records report for sleeves that are in footings at time of next inspection
 do not pour
- 3 1. cancelled per contractor

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org