



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Aug 03, 2023

**Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRSG20230449

**Property Address:** 3811 9TH ST SW, PUYALLUP, WA 98373;

**Contractor:** TACOMA TENT & AWNING 121 N "G" TACOMA, WA 98403

**To construct:** Construction of New Awning ~ SALUD BAR & GRILL

On this day we have inspected your construction for **Sign Attachment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; inspection of footings only. ( anchors not installed at time of inspection )  
2 ; provide engineers fix for epoxy of holdowns not installed at footing inspection.

**Corrections:**

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684