



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

## INSPECTION REPORT

**Date of Inspection:** Aug 03, 2023 **Inspection Result:** **PARTIAL PASS**

**Permit Number:** PRCTI20230310

**Property Address:** 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

**Contractor:** ELITE MECHANICAL SERVICES LLC 8304 WOODGROVE CT SE OLYMPIA, WA 98513

**To construct:** ±130,912 SF, NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT:  
WORK INCLUDES NON-STRUCTURAL  
DEMOLITION, NEW PARTITIONS, DOORS, AND FINISHES.

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. ok to insulate duct as discussed
- 2.no seismic was in place at time of inspection
- 3.smoke damper was not in place at time of inspection
4. cold air return drops where not installed at time of inspection

Sincerely,

Kevin Spruell  
Building Inspector I  
[KSpruell@PuyallupWA.gov](mailto:KSpruell@PuyallupWA.gov)  
(253) 841-5590