



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 04, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** B-21-0225

**Property Address:** 401 15TH AVE SE, PUYALLUP, WA 98372;

**Contractor:** HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

**To construct:** BUILD-OUT OF OR 7 & 8 IN EXISTING SHELL SPACE ~VALLEY  
TOWER/2ND FL

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** 1 ; ok to insulate duct in O.R.7&8 ( mechanical inspection only)

**Corrections:**

- 1 1 ; complete framing as per city approved plans. ( inspection of OR7 & OR8 only)
- 2 ; provide electrical cover approval prior to frame inspection.
- 3 ; complete nail plates at electrical as discussed with contractor.
- 4 ; plumbing approved as noted on sheet m3.02 of approved plans (d.w.v. and supply only)
- 5 ; mechanical approved as noted on sheet m4.02 Of city approved plans.

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

(253) 840-6684