



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 07, 2023

Inspection Result: **FAILED**

Permit Number: PRFS20230412

Property Address: 3811 9TH ST SW, PUYALLUP, WA 98373;

Contractor: EVERGREEN FIRE PROTECTION 10509 64TH AVE E PUYALLUP, WA 98373

To construct: Add (2) dry horizontal sidewalls and modify (9) existing pendent heads ~ SALUD BAR & GRILL

On this day we have inspected your construction for **Hydrostatic Test 200Lbs 2Hrs** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

1. 1. Awning is not installed to verify clearances.
2. 2. Out of the two sprinkler pipes, the south pipe was at an angle coming through the wall improperly installed or not attached at all.
3. 3. No plans onsite.
4. 4. Next available inspection is Monday.
2. Complete previous corrections

Sincerely,

David Drake
Building Inspector II
DDrake@PuyallupWA.gov
(253) 864-4171



City of Puyallup

Fire Prevention

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org