



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 16, 2023                      **Inspection Result:**      **PARTIAL PASS**

**Permit Number:** PRCCP20220770

**Property Address:** 1601 39TH AVE SE, PUYALLUP, WA 98374;

**Contractor:** ABSHER CONSTRUCTION CO PO BOX 280 PUYALLUP, WA 98371-0152  
Raygan Kettman 1001 SHAW RD E PUYALLUP, WA 98372

**To construct:** The project proposes a new STEM classroom and laboratory building and a new parking lot, net gain of 100 stalls. Improvements include asphalt paving, concrete paving, a new building, utilities services for the new building, and stormwater management. Utility services include domestic water and water main, sewer main and services, natural gas, primary and secondary power, and telecommunications. Modifications to the existing parking lot east of the building and sidewalks adjacent to the building will occur. A belowground detention facility utilizing Stormtech MC-7200 chambers are proposed for stormwater flow control. A bioretention facility will be used upstream of the proposed flow control facility to provide stormwater quality treatment for pollution generating impervious surfaces (PGIS).

On this day we have inspected your construction for **Engineering Daily Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** I called the Water Management Labs at 315pm to get a verbal on all water samples.

- The water samples from 8/14/23 were both good.
  - The water samples from 8/15/23 were both good as well.
- Tunista can tie in the water main on both ends.

**Corrections:**

- 1 - Clean sewer main between SSMH 1, 2, & 3. See TV prior to asking why.
  - July 29th or later, the mandrel can be pulled again.
  - Keep plug in SSMH 5 to keep construction debris out.



City of Puyallup

**Engineering Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

- Install 6" tee with in 4' of the building c/o.

Sincerely,

Jason Little  
Engineering Tech IV  
[JLittle@PuyallupWA.gov](mailto:JLittle@PuyallupWA.gov)  
(253) 435-3636