



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Aug 24, 2023 **Inspection Result:** **FAILED**

Permit Number: B-20-0078

Property Address: 1515 S MERIDIAN, PUYALLUP, WA 98371;

Contractor: BALDWIN GENERAL CONTRACTING PO BOX 686, 0876 ALBANY, OR 93721

To construct: HAMPTON INN ADDITION & PARKING BELOW E-20-0052
PRGR20230876

On this day we have inspected your construction for **Footing/Setback Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide Geo-tech approval for soil bearing of 4,000 psf as required per structural sheets of city approved plans.
- 2 ; complete vert. rebar as per city approved plans at grid line - (A-B,1-3.5)
- 3 ; complete pier pads at grid line -(G-H,4-5) (5,b.5) (A,5-6) not completed at time of inspection.
- 4 ; provide detail from engineer of record for step at grid line - (1.c.5)

Sincerely,

Shannon King
Building Inspector 2



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

ShannonK@PuyallupWA.gov

(253) 840-6684