

Air System Sizing Summary for HP-3

Project Name: Absher Construction Replace HP-3
 Prepared by: Air Systems Engineering



08/09/2023
 09:45AM

Air System Information

Air System Name **HP-3**
 Equipment Class **SPLT AHU**
 Air System Type **SZCAV**

PRMH20231183

Number of zones **1**
 Floor Area **1976.0** ft²
 Location **Tacoma, Washington**

Sizing Calculation Information

Calculation Months **Jan to Dec**
 Sizing Data **Calculated**

Zone CFM Sizing **Sum of space airflow rates**
 Space CFM Sizing **Individual peak space loads**

Central Cooling Coil Sizing Data

Total coil load **4.4** Tons
 Total coil load **52.4** MBH
 Sensible coil load **51.4** MBH
 Coil CFM at Jun 1600 **2815** CFM
 Max block CFM **2815** CFM
 Sum of peak zone CFM **2815** CFM
 Sensible heat ratio **0.981**
 CFM/Ton **644.2**
 ft²/Ton **452.1**
 BTU/(hr-ft²) **26.5**
 Water flow @ 10.0 °F rise **N/A**

Load occurs at **Jun 1600**
 OA DB / WB **84.3 / 64.8** °F
 Entering DB / WB **77.1 / 64.9** °F
 Leaving DB / WB **60.0 / 58.8** °F
 Coil ADP **58.1** °F
 Bypass Factor **0.100**
 Resulting RH **54** %
 Design supply temp. **58.0** °F
 Zone T-stat Check **1 of 1** OK
 Max zone temperature deviation **0.0** °F

Central Heating Coil Sizing Data

Max coil load **29.8** MBH
 Coil CFM at Des Htg **2815** CFM
 Max coil CFM **2815** CFM
 Water flow @ 20.0 °F drop **N/A**

Load occurs at **Des Htg**
 BTU/(hr-ft²) **15.1**
 Ent. DB / Lvg DB **65.3 / 75.2** °F

Supply Fan Sizing Data

Actual max CFM **2815** CFM
 Standard CFM **2783** CFM
 Actual max CFM/ft² **1.42** CFM/ft²

Fan motor BHP **0.00** BHP
 Fan motor kW **0.00** kW
 Fan static **0.00** in wg

Outdoor Ventilation Air Data

Design airflow CFM **231** CFM
 CFM/ft² **0.12** CFM/ft²

CFM/person **15.40** CFM/person

Air System Design Load Summary for HP-3

Project Name: Absher Construction Replace HP-3
 Prepared by: Air Systems Engineering



08/09/2023
 09:45AM

	DESIGN COOLING			DESIGN HEATING		
	COOLING DATA AT Jun 1600			HEATING DATA AT DES HTG		
	COOLING OA DB / WB 84.3 °F / 64.8 °F			HEATING OA DB / WB 18.0 °F / 14.8 °F		
ZONE LOADS	Details	Sensible (BTU/hr)	Latent (BTU/hr)	Details	Sensible (BTU/hr)	Latent (BTU/hr)
Window & Skylight Solar Loads	320 ft ²	20241	-	320 ft ²	-	-
Wall Transmission	1352 ft ²	2580	-	1352 ft ²	4396	-
Roof Transmission	1976 ft ²	4296	-	1976 ft ²	3714	-
Window Transmission	320 ft ²	1087	-	320 ft ²	9784	-
Skylight Transmission	0 ft ²	0	-	0 ft ²	0	-
Door Loads	0 ft ²	0	-	0 ft ²	0	-
Floor Transmission	1976 ft ²	0	-	1976 ft ²	0	-
Partitions	0 ft ²	0	-	0 ft ²	0	-
Ceiling	0 ft ²	0	-	0 ft ²	0	-
Overhead Lighting	3162 W	10787	-	0	0	-
Task Lighting	1482 W	5056	-	0	0	-
Electric Equipment	988 W	3371	-	0	0	-
People	15	3675	3075	0	0	0
Infiltration	-	0	0	-	0	0
Miscellaneous	-	0	0	-	0	0
Safety Factor	0% / 0%	0	0	0%	0	0
>> Total Zone Loads	-	51093	3075	-	17894	0
Zone Conditioning	-	49502	3075	-	17103	0
Plenum Wall Load	0%	0	-	0	0	-
Plenum Roof Load	0%	0	-	0	0	-
Plenum Lighting Load	0%	0	-	0	0	-
Return Fan Load	2815 CFM	0	-	2815 CFM	0	-
Ventilation Load	231 CFM	1937	-2075	231 CFM	12710	0
Supply Fan Load	2815 CFM	0	-	2815 CFM	0	-
Space Fan Coil Fans	-	0	-	-	0	-
Duct Heat Gain / Loss	0%	0	-	0%	0	-
>> Total System Loads	-	51439	1000	-	29813	0
Central Cooling Coil	-	51439	1008	-	0	0
Central Heating Coil	-	0	-	-	29813	-
>> Total Conditioning	-	51439	1008	-	29813	0
Key:	Positive values are clg loads Negative values are htg loads			Positive values are htg loads Negative values are clg loads		

System Psychrometrics for HP-3

Project Name: Absher Construction Replace HP-3
 Prepared by: Air Systems Engineering



08/09/2023
 09:45AM

WINTER DESIGN HEATING

TABLE 1: SYSTEM DATA

Component	Location	Dry-Bulb Temp (°F)	Specific Humidity (lb/lb)	Airflow (CFM)	CO2 Level (ppm)	Sensible Heat (BTU/hr)	Latent Heat (BTU/hr)
Ventilation Air	Inlet	18.0	0.00098	231	400	-12710	0
Vent - Return Mixing	Outlet	65.3	0.00098	2815	511	-	-
Central Cooling Coil	Outlet	65.3	0.00098	2815	511	0	0
Central Heating Coil	Outlet	75.2	0.00098	2815	511	29813	-
Supply Fan	Outlet	75.2	0.00098	2815	511	0	-
Cold Supply Duct	Outlet	75.2	0.00098	2815	511	-	-
Zone Air	-	69.5	0.00098	2815	521	-17103	0
Return Plenum	Outlet	69.5	0.00098	2815	521	0	-

Air Density x Heat Capacity x Conversion Factor: At sea level = 1.080; At site altitude = 1.067 BTU/(hr-CFM-F)

Air Density x Heat of Vaporization x Conversion Factor: At sea level = 4746.6; At site altitude = 4691.6 BTU/(hr-CFM)

Site Altitude = 322.0 ft

TABLE 2: ZONE DATA

Zone Name	Zone Sensible Load (BTU/hr)	T-stat Mode	Zone Cond (BTU/hr)	Zone Temp (°F)	Zone Airflow (CFM)	CO2 Level (ppm)	Terminal Heating Coil (BTU/hr)	Zone Heating Unit (BTU/hr)
Zone 1	-17894	Heating	-17103	69.5	2815	521	0	0