



CITY OF PUYALLUP
Development & Permitting Services
333 S. Meridian, Puyallup, WA 98371
(253) 864-4165
www.cityofpuyallup.org

Permit No:
PRFA20231139

FIRE ALARMS

Puyallup, WA

Job Address	Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371 Parcel # 0420212076	ISSUED August 28, 2023
Owner AMB INSTITUTIONAL ALLIANCE FUND III LP 1800 WAZEE ST DENVER, CO 80202		
Applicant Jeffrey Harasimowitz 2707 70th Ave. East Tacoma, WA 98424 (253) 284-3447 jeffh@patriotfire.com		
Contractor PATRIOT FIRE PROTECTION 2707 70TH AVE E TACOMA, WA 98424 WA L&I #:		
Description of Work (1) ALARM PROLOGIS SUTIE 101		
Permit Types	Fire Alarms	
Expiration Date: February 24, 2024		
Total ESU's		

Building Components:

Quantity	Units	Description
20	DEVICES	Fire Alarm and Detection System and Related Equipment, Alteration
145	DEVICES	Fire Alarm and Detection System and Related Equipment, New
Total Value of Work:		\$0.00

Standard Conditions:

- 1- APPOINTMENT REQUIRED FOR ALL INSPECTIONS
- 2- PROVIDE PLANS AND PERMIT ON SITE FOR INSPECTION.
- 3- COMPLETE LABOR AND INDUSTRIES INSPECTIONS PRIOR TO REQUESTING CITY INSPECTION.
- 4- A REMOTE ANNUNCIATOR LOCATED ON THE EXTERIOR OF THE MAIN ENTRANCE IN A WEATHER PROOF HOUSING REQUIRED.
- 5- EXTERIOR FIRE BELL REQUIRED OUTSIDE FIRE SPRINKLER ROOM.
- 6- DEVICE MAPS REQUIRED AT THE ANNUNCIATOR AND FIRE ALARM PANEL PRIOR TO CALLING IN FINAL. THE ANNUNCIATOR MAP WILL NEED TO BE WEATHER PROOF.
- 7- TOTAL COVERAGE IS REQUIRED; SUBJECT TO FIELD INSPECTION. COMPLY WITH NFPA 72, 2013
- 8- FIRE ALARM SYSTEM SHALL BE PLACARDED PER NFPA 72. THE UL CERTIFICATE SHALL BE POSTED AT TIME OF FINAL INSPECTION. THE SYSTEM WILL NEED TO BE UL CERTIFIED.

- 9- A PRE-TEST SHALL BE CONDUCTED AND A PRINT OUT OF THE LOCATION OF THE DEVICE, POINT NUMBER AND DESCRIPTOR SHALL BE FURNISHED TO THE INSPECTOR AT FINAL.
- 10- FIRE SPRINKLER TAMPER VALVES AND PIV WILL BE REQUIRED TO BE TESTED AT INSPECTION. FIRE SPRINKLER CONTRACTOR TO BE ONSITE.
- 11- THE CITY OF PUYALLUP ALLOWS ONE FACP PER BUILDING. THE PANEL WILL NEED TO BE LARGE ENOUGH TO HANDLE MULTIPLE TENTANTS IF APPLICABLE.

Permit is valid 180 days from date of issuance. Permit validity is subject to all adhering to all applicable codes, ordinances and standards, and conditions of this permit.

I certify that I am the owner of this property or the owner's authorized agent, including an appropriately licensed contractor. I have read and examined this application and furnished true and correct information. I will comply with all provisions of law and ordinances governing this type of construction work, whether specific herein or not. By submitting this application, I give the jurisdiction permission to enter the property to perform inspections. The granting of this permit does not presume or give authority to violate or cancel the provisions of any other state or local law regulating construction or the performance of construction. I understand that failure to comply with the above may result in revocation of the permit.

Applicant:
Jeffrey Harasimowitz