



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 28, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20230304

**Property Address:** 1102 E MAIN, PUYALLUP, WA 98372;

**Contractor:** PINNACLE CONSTRUCTION INC PO BOX 426 GLENWOOD, IA 51534

**To construct:** Interior building remodel. New electrical . New plumbing supply lines .  
Two new bathrooms along with air supply and connections to existing  
sewer. Relocate hot water heater and provide new exit door. New  
insulation ceilings and cosmetic improvements throughout.

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. provide header at new exterior door .  
2.provide engineering for stud repair at bearing wall as discussed with contractor  
3. provide min threshold ht at door to landings interior and exterior as discussed with contractor  
4. tenant in back space needs to meet with city to obtain occupancy
- 2 1. header at exterior door approved  
2.stud repair at exterior wall approved  
3. ok to insulate

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)