



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Aug 29, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRMH20231156

**Property Address:** 2504 E MAIN, PUYALLUP, WA 98372;

**Contractor:** UNIVERSAL REFRIGERATION PO BOX 614 AUBURN, WA 98071-0614

**To construct:** 1. INSTALL (3) ENERGY RECOVERY VENTILATORS.2. INSTALL (2) ROOFTOP EXHAUST BLOWERS.3. INSTALL (1) OUTDOOR SECTION HEAT PUMP UNIT.4. INSTALL (5) INDOOR FAN COIL UNITS.6. INSTALL DUCTWORK, GRILLES & REGISTERS.

On this day we have inspected your construction for **Mechanical Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 1 1. duct seal approved only
- 2.provide city approved plans on site at time of next inspection
- 3.provide letter from engineer of record for the relocation of equipment being outside the conditioned space
4. provide letter from engineer of record specifying insulation on ductwork outside of the conditioned space
5. no city approved plans where on site at time of inspection

Sincerely,

Kevin Spruell  
Building Inspector I  
KSpruell@PuyallupWA.gov  
(253) 841-5590



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)