

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection:	Sep 01, 2023	Inspection Result:	NOT READY
Permit Number: Property Address:	B-20-0180 3601 9TH ST SW, PUYAI	LUP, WA 98373;	
Contractor:	THARALDSON HOSPITA 58104 Roger Olson 452	LITY DEV LLC 4520 36TH 0 36th ave s fargo, ND	
To construct:	HOMEWOOD SUITES SO	0	
	REVISION (1) 6/8/2023 - VALUE ENGINEER FOOTINGS AND ADD		
	PERIMETER DRAINTILE		

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

4 1.foundation wall inspection for perimeter
2.complete rebar at elevator pit per city approved plans
3.provide detail sheet for sleeve thru wall at time of next inspection
4.provide step clarification from engineer of record at time of next inspection
5.clarify if special inspection is required for water stop
6.provide lap schedule for rebar at time of next inspection
7.provide new special inspections reports to support corrections

Sincerely,

Kevin Spruell Building Inspector I KSpruell@PuyallupWA.gov (253) 841-5590



City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org