



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 01, 2023

Inspection Result: **PARTIAL PASS**

Permit Number: B-21-0225

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: BUILD-OUT OF OR 7 & 8 IN EXISTING SHELL SPACE ~VALLEY
TOWER/2ND FL

On this day we have inspected your construction for **Combination Frame And Rough In Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1. ok to cover wall

Corrections:

- 1 1 ; complete framing as per city approved plans. (inspection of OR7 & OR8 only)
- 2 ; provide electrical cover approval prior to frame inspection.
- 3 ; complete nail plates at electrical as discussed with contractor.
- 4 ; plumbing approved as noted on sheet m3.02 of approved plans (d.w.v. and supply only)
- 5 ; mechanical approved as noted on sheet m4.02 Of city approved plans.

Sincerely,

Kevin Spruell
Building Inspector I
KSpruell@PuyallupWA.gov
(253) 841-5590