




PRFS20231165



(253) 926-1880 · FAX (253) 926-2350

SMITH FIRE SYSTEMS, INC.

1106 54th Avenue East · Tacoma, Washington 98424

August 7, 2023

Attention: Plan Review

Reference:

GSMOB Women's 3rd Floor TI
1450 5th St SE
Puyallup, WA.

SFS Job #: TI23046

To whom it may concern:

The above referenced fire sprinkler project being submitted for a fire sprinkler permit is a tenant improvement to an existing sprinkler system. The modifications are limited to adding and/or relocating sprinkler drops to accommodate the new tenant ceilings and walls. The pipe sizing, selection of sprinklers, and the spacing of sprinklers will be made in accordance with the existing system's design criteria. The modifications do not affect the hydraulic calculations. No new hydraulic calculations are necessary, and no new calculations are being submitted with this permit application.

Thank you