

Date: August 18th, 2023
RE: Meridian Shopping Center
4621 S Meridian Ave Puyallup, WA 98373

To whom it may concern:

Your comments are reproduced below in *italics*, and the comment responses are immediately following the comments. The permit resubmittal package includes the following documents:

1. *Mechanical Plans – File must have restriction removed; we do not have access for stamping/markups otherwise.*
Please see revised stamp set.
2. *Energy Code Worksheets – Not received.*
This is like-for-like equipment that is not adding capacity to the building. There are energy notes on the cover sheet for compliance to the code, economizer, and documentation to the owner. The permit office didn't think these worksheets would be necessary (when I called).
3. *Floor Plan – Not received.*
There are no changes to the ductwork, just rooftop equipment replacement. The permit office didn't think a floor plan would be necessary (when I called).

Sincerely,

Austin Hanks
AustinHanks@auburnmechanical.com
253-838-9780