



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 07, 2023

**Inspection Result:** PARTIAL PASS

**Permit Number:** PRCTI20221793

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construction of a swim school including the pool in the former Sears  
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Ceiling Grid/T-Bar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:**

**Corrections:**

- 2 1 ; complete firestop of penetrations at rated wall above ceiling at south wall in room - 101 office. (ok to cover except 1 tile for reinspection)

Sincerely,

Shannon King  
Building Inspector 2  
ShannonK@PuyallupWA.gov  
(253) 840-6684