



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 11, 2023

Inspection Result: PARTIAL PASS

Permit Number: PRCTI20230656

Property Address: 1450 5TH ST SE, PUYALLUP, WA 98372;

Contractor: ABBOTT CONSTRUCTION 3408 1ST AVENUE SOUTH SEATTLE, WA 98134
Sam Eastman 2500 Holgate St Tacoma, WA 98402

To construct: An 853 SF tenant improvement to the the existing Women's Clinic Suite 3100, located on the 3rd floor, including exam rooms and patient and staff support areas. MULTICARE WOMEN'S CLINIC

On this day we have inspected your construction for **Firewall/Firestop Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: 1 ; firestop complete at bottom track of wall framing.

Corrections:

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684