



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 11, 2023

Inspection Result: **FAILED**

Permit Number: PRCTI20230310

Property Address: 1601 INDUSTRIAL PARK WAY, PUYALLUP, WA 98371;

Contractor: ELITE MECHANICAL SERVICES LLC 8304 WOODGROVE CT SE OLYMPIA, WA 98513

To construct: ±130,912 SF, NON-STRUCTURAL INTERIOR TENANT IMPROVEMENT:
WORK INCLUDES NON-STRUCTURAL
DEMOLITION, NEW PARTITIONS, DOORS, AND FINISHES.

On this day we have inspected your construction for **Shear Wall Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1. partial approval as marked up on plans sheet AI101
- 2 1. treated plywood completed and approved
- 3 1. vapor barrier approved
- 4 1. rigid foam approved
- 5 1. cancelled by contractor
- 6 1. furring strip attachment approved 8/30/2023
- 7 1. removed 5 sheets of drywall to verify seams breaking on furring strips per city approved plans 3 locations did not. provide clarification from architect that what is on site is acceptable to his design
2. there was no drywall nailing looked at at time of inspection
date 09/11/2023

Sincerely,

Kevin Spruell



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

Building Inspector I

KSpruell@PuyallupWA.gov

(253) 841-5590