



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 12, 2023

Inspection Result: **FAILED**

Permit Number: PRMH20231198

Property Address: 4621 S MERIDIAN, Unit: A825, PUYALLUP, WA 98373;

Contractor: AUBURN MECHANICAL, INC. PO BOX 249 AUBURN, WA 98071

To construct: We are replacing (5) rooftop package heat pumps, all like in kind.

On this day we have inspected your construction for **Mechanical Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide balance report as noted on City approved plans.

Sincerely,

Shannon King
Building Inspector 2
ShannonK@PuyallupWA.gov
(253) 840-6684