

ATTN: CITY OF PUYALLUP – PERMIT CENTER

RE: PRHM20231131-MH1 PERMIT CORRECTIONS RESPONSE

DATE: 09.13.2023

To whom it may concern,

Provide gas diagram how both Unit Heaters will tie into existing gas, include total develop line to assure it is adequately sized for new equipment. Sheet M202

Existing and new Gas piping and meter locations have been added to sheet M202

Please do not hesitate to reach out with questions or additional documentation.

Sincerely,



Tricia Drake, PE, LEED AP
PE in WA, ID, OR, CA
Founder and Principal

HVAC Double Check LLC
tricia@hvacdoublcheck.com
206.249.6154



206.249.6154



tricia@hvacdoublcheck.com



Spokane, WA



hvacdoublcheck.com