

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT


Date of Inspection:	Sep 14, 2023	Inspection Result:	PASSED W/ CONDITIONS
	PRRASF20221703 1404 SHAW RD, PUYALL	UP, WA 98372;	
Contractor:	MICHAEL E ALLEN CONS 1600	ST INC 3623 32ND AVE E	TACOMA, WA 98443-
To construct:	Building an addition of 2 square feet.	2,905 square feet with a 2	2 car garage of 732

On this day we have inspected your construction for **Erosion And Sediment Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: Maintain cover on piles. Once foundation is backfilled, straw site to maintain run off. Protect the bio swale.

Corrections:

Sincerely,





City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

Jason Little Engineering Tech IV JLittle@PuyallupWA.gov (253) 435-3636