

City of Puyallup Building Division 333 S. Meridian, Puyallup, WA 98371 (253) 864-4165 www.cityofpuyallup.org

INSPECTION REPORT

| Date of Inspection: | Sep 14, 2023 | Inspection Result: | PARTIAL PASS | S |
|-------------------------------------|-------------------------------------|----------------------|----------------|-------|
| Permit Number: Property Address: | B-20-0078 1515 S MERIDIAN, PUYA | ALLUP, WA 98371; | | |
| Contractor: | BALDWIN GENERAL CO 93721 | NTRACTING PO BOX 686 | o, 0876 ALBANY | (, OR |
| To construct: | HAMPTON INN ADDITIC PRGR20230876 | on & Parking Below e | -20-0052 | |

On this day we have inspected your construction for **Foundation/Rebar Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments: progress with special inspection. (pending special inspection report)

Corrections:

- 1 1. provide letter for no changes needed at step in foundation from engineer of record
 - 2. ok to pour per special inspection approval footings only

Sincerely,

Shannon King Building Inspector 2 ShannonK@PuyallupWA.gov (253) 840-6684