



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

INSPECTION REPORT

Date of Inspection: Sep 14, 2023

Inspection Result: NOT READY

Permit Number: B-21-0225

Property Address: 401 15TH AVE SE, PUYALLUP, WA 98372;

Contractor: HOWARD S WRIGHT 415 1ST AVE N SEATTLE, WA 98109

To construct: BUILD-OUT OF OR 7 & 8 IN EXISTING SHELL SPACE ~VALLEY
TOWER/2ND FL

On this day we have inspected your construction for **Frame Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

Comments:

Corrections:

- 1 1 ; provide city approved plans and engineering on-site for inspection of hard lids. not ready
- 2 1 ; provide engineering on-site for inspection of hard lids in O.R. 7&8. not ready
- 3 1 ; provide engineering for hard lid ceiling in O.R 7&8 as discussed with contractor.
2 ; complete framing as per engineering at bracing removed as discussed with contractor.
not ready

Sincerely,

Shannon King

Building Inspector 2

ShannonK@PuyallupWA.gov

(253) 840-6684



City of Puyallup

Building Division

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org