



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

## INSPECTION REPORT

**Date of Inspection:** Sep 15, 2023                      **Inspection Result:**     **PARTIAL PASS**

**Permit Number:** PRCTI20221793

**Property Address:** 3500 S MERIDIAN, Unit: 930, PUYALLUP, WA 98373;

**Contractor:** WASHINGTON PATRIOT CONST LLC 10421 BURNHAM DR SUITE NW  
GIG HARBOR, WA 98332

**To construct:** Construction of a swim school including the pool in the former Sears  
store located in the South Hill Mall ~ GOLDFISH SWIM SCHOOL

On this day we have inspected your construction for **Building Final Inspection** and we find the following result of the inspection. If there are any questions, please contact the inspector below.

**Comments:** approved as noted of correction report dated 9/15/2023

**Corrections:**

- 1 1 ; secure hot water tank prior to next inspection. \*
- 2 ; complete install of self closer at acid room door.
- 3 ; insulate all hot water supply lines in boiler room.
- 4 ; complete all T.P.R. valve drains to mop sink. \*
- 5 ; complete drain for backflow to mop sink.
- 6; complete all permanent signage at exit doors ,restrooms, changing rooms, occupant load signage as per City approved plans. \*
- 7 ; complete plumbing boots at sinks at restrooms. \*
- 8 ; complete ceiling at electrical room. \*
- 9 ; complete accessible benches in restroom as per City approved plans. \*
- 10 ; complete urinal 17" max. a.f.f. in restroom as per City approved plans. \*
- 11 ; complete handrail at stairs as per City approved plans. \*
- 12 ; remove all construction debris from accessible route,parking lot and containers as discussed with contractor. \*
- 13; remove all construction debris from roof.
- 14 ; paint all new gas pipe on roof and next to gas meter.
- 15 ; approved for training for 10 working days from 9/15/2023
- 16 - items with \* required for t.c.o.



City of Puyallup

---

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

[www.cityofpuyallup.org](http://www.cityofpuyallup.org)

Sincerely,

Shannon King  
Building Inspector 2  
[ShannonK@PuyallupWA.gov](mailto:ShannonK@PuyallupWA.gov)  
(253) 840-6684