



City of Puyallup

**Building Division**

333 S. Meridian, Puyallup, WA 98371

(253) 864-4165

www.cityofpuyallup.org

# Permit Review Correction Letter

## Permit Application #PRMU20221555 – REVISION (1)

September 19, 2023

The City has completed the review of the above-mentioned permit REVISION. All of your review comments, conditions, and redlined plans can be found on the [City's permit portal](#). Redlined plans can be found on the City's Permit Portal in the "Reviews" section under "Documents Returned for Corrections". Below please find the permit submittal review comments from your review team and re-submittal instructions. Should you have any questions regarding the review comments, please contact the plan reviewer associated with the comment listed below.

### Re-submittal Instructions

To resubmit, you must address all comments and complete and submit a correction response letter.

- 1 When you are ready to resubmit the revision documents addressing the below noted corrections, please email them (along with your corrections response letter) to [permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov).
- 2 You will need to pay your resubmittal fee at the time of resubmittal. Your revision resubmittal will not be processed until the fee has been paid.

### Corrections

Corrections to be addressed on the next set of resubmitted plans:

<b>Engineering Review</b>	<b>Linda Lian</b>	<b>(253)841-5577</b>	<b>LindaL@PuyallupWA.gov</b>
<ul style="list-style-type: none"> <li>- Explain this slope. It does not coincide with the Plan View/ Site Plan [Copperbary_4002 10th St SE-C1.0 RTEAINING WALL FOR NORTH AND SOUTH BLDGES Sheet 1 of 1]</li> <li>- Lowering the footing to 8' (ft) would bring the sewermain out of the zone of influence [Copperbary_4002 10th St SE-C1.0 RTEAINING WALL FOR NORTH AND SOUTH BLDGES Sheet 1 of 1]</li> </ul>			

- Provide the elevation of the bottom of the footing [Copperbary\_4002 10th St SE-C1.0 RTEAINING WALL FOR NORTH AND SOUTH BLDGES Sheet 1 of 1]
- Provide the elevation of the top of the sewermain [Copperbary\_4002 10th St SE-C1.0 RTEAINING WALL FOR NORTH AND SOUTH BLDGES Sheet 1 of 1]

If you need assistance with resubmitting your corrections, please contact the Permit Center.

Sincerely,

City of Puyallup Permit Center  
(253) 864-4165 option 1  
[permitcenter@puyallupwa.gov](mailto:permitcenter@puyallupwa.gov)